

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

**Attn:** Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122**Phone:** (212) 477-8941**Received:** 3/9/02

5:00:00 PM

ATC Group #: 7001**Analysis Date:** 3/9/02**Project:** NYC BOE H.S. For Leadership & Public Services

90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm²)	(S/cc)	
04 7001 -1	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
05 7001 -2	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
06 7001 -3	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 7001 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7001 -5	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 7001 -6	1800.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 7001 -7	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 7001 -8	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PRYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limit) and laboratory and analysis accuracy and precision is available upon request.

Accredited for NYLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002919030