

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC - BOE PS 234 M
292 Greenwich Street, New York, NY

Received: 12/1/01 4:45:00 PM

ATC Group #: 6015

Analysis Date: 12/2/01


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5μ-5 μ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
01 6015 -1	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 6015 -2	1908.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 6015 -3	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 6015 -4	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 6015 -5	1908.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 6015 -6	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 6015 -7	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
08 6015 -8	1908.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002890708

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 12/1/01 4:45:00 PM

ATC Group #: 6015

Analysis Date: 12/2/01


Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC - BOE PS 234 M
292 Greenwich Street, New York, NY


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
09 6015 -9	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
10 6015 -10	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
11 6015 -11	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
12 6015 -12	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
13 6015 -13	1908.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
14 6015 -14	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
15 6015 -15	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 6015 -16	1890.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
17 6015 -17	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
18 6015 -18	1899.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002890709