


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3TIME 12:45LOCATION PS 234 MDATE 1/24/02PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
^{East} Outside	—	51.4	77.7	524	0	42	0
Hall by 104		68.0	76.3	801	0	40	0
^{North} Outside	—	52.9	81.9	585	1	56	0
^{South} Outside		52.6	80.7	526	1	60	0
^{West} Outside		53.1	79.7	558	0	59	0
Lunch Room	—	67.3	70.7	680	0	46	0
Gym (1st Fl.)		66.4	65.3	651	1	40	0
Hall by Exit 1		66.5	59.1	570	1	39	0
Hall by ^{West} Exit		66.0	55.2	576	1	38	0
120		65.8	51.3	581	1	41	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/24/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3TIME 13:00LOCATION PS 234 MDATE 1/24/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Stair H3		67.9	48.7	622	0	38	0
220		64.6	45.1	570	0	32	0
216		66.1	43.2	571	0	32	0
229		66.9	44.2	688	0	35	0
223 (Hall)		67.7	43.9	630	0	32	0
223		68.3	44.0	730	0	34	0
Assembly (Hall)		68.8	41.9	690	0	34	0
211		68.9	41.4	669	0	35	0
Hall by 201		68.8	40.6	642	0	36	0
Stair H2		68.2	41.2	690	0	48	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 1/24/02


CITY_21MC100_002891093

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3TIME 13:15LOCATION PS 234 M DATE 1/24/02 PROJECT NO. 19125 - 279

Location	Occup	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301		65.2	41.3	616	1	65	0
305		65.3	40.7	588	1	61	0
304		65.9	40.3	617	0	61	0
315		66.5	40.5	600	0	56	0
Hall by Elevator		66.6	40.5	595	0	42	0
323		66.0	40.3	595	0	40	0
Hall by ^{Exit} #1		65.9	40.1	613	0	41	0
329		65.1	41.4	576	0	42	0
316		64.2	41.8	846	0	34	0
318		64.4	41.5	790	0	39	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 1/24/02