

7:20 AM

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 2

LOCATION PS 234DATE 4-26-02PROJECT NO. 19125 - 279

occupy

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
	OUTSIDE						
C	MAIN ENTRANCE	64.9	20.2	465	2	20	0
2	NEXT TO MAIN DESK (IN)	64.9	20.4	510	2	21	0
C	NORTH WEST CORNER	64.6	20.6	461	2	19	0
C	WESTSIDE	64.9	20.7	465	2	19	0
C	SOUTHWEST CORNER	64.9	21.1	465	2	19	0
C	COURTYARD	65.1	21.2	465	2	18	0
C	NORTH EAST CORNER	65.1	20.9	465	2	17	0
C	MAIN ENTRANCE	65.3	20.9	477	2	19	0
C	SOUTHEAST CORNER	65.6	20.4	471	2	19	0
C	SOUTHSIDE	65.4	20.6	486	2	19	0
	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

4-26-02

3⁴⁵pm

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

LOCATION PS 234 DATE 4-26-02 PROJECT NO. 19125-279

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
cccupl							
4	CATERIA	71.0	22.1	796	2	15	0
0	HALL BY GYM	71.0	21.7	510	2	14	0
0	GYM	71.0	21.6	487	2	15	0
0	MAIN FOYER	71.9	21.6	489	2	15	0
0	MAIN DESK	71.9	21.1	499	2	12	0
0	HALL BY ELEVATOR	71.9	21.9	521	2	11	0
0	HALL BY EXIT 1	71.9	21.9	516	2	15	0
0	114 HALLWAY	71.6	22.9	501	2	15	0
16	116	70.9	22.1	966	2	15	0
17	118	70.6	22.9	981	2	17	0
	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

CITY_21MC100_002920379

2:34 pm

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6

LOCATION PS 234 DATE 4-26-02 PROJECT NO. 19125-279

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
C	HALLWAY NEXT TO STAIRWELL 13	70.2	22.3	516	2	15	C
C	120	70.1	21.9	499	2	16	C
C	122	69.9	22.3	491	2	16	C
C	222	71.6	23.1	496	2	16	C
C	220	71.2	21.8	516	2	16	C
C	218 HALLWAY	70.6	21.8	519	2	17	C
C	216	70.6	22.9	521	2	14	C
C	212	71.1	24.6	536	2	13	C
C	229	71.1	24.6	521	2	15	C
C	227 HALLWAY	70.9	24.7	519	2	16	C
	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4-2-02

140
pm

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6

LOCATION PS 234 M DATE 4-26-02 PROJECT NO. 19125 - 279

Occup	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
C	Hall 210	70.9	25.0	500	2	15	C
C	225	70.9	25.1	477	2	16	C
C	223	70.6	24.9	491	2	17	C
C	Next to Elevator Bank	70.2	24.9	499	2	18	C
C	214	70.3	24.9	506	2	19	C
C	206	69.9	24.9	503	2	15	C
C	206 Hallway	69.9	25.3	502	2	14	C
16	215	70.1	25.6	899	2	16	C
17	211	71.1	25.1	927	2	16	C
C	201	71.6	24.3	509	2	16	C
	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4-26-02

CITY_21MC100_002920381

500
pm

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6

LOCATION PS 234 M DATE 4-26-02 PROJECT NO. A125-279

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
202	69.9	21.9	996	2	19	0
301	71.2	22.1	499	2	18	0
302 Hall	69.1	22.3	496	2	20	0
305	69.9	22.6	1010	2	15	0
304	70.1	22.9	491	2	15	0
311	70.2	21.9	491	2	15	0
306	70.3	22.6	1101	2	15	0
315	70.2	22.6	988	2	12	0
308	70.6	22.9	510	2	14	0
319	71.1	22.9	516	2	15	0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 4-26-02

2:00 pm

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

LOCATION PS 234 M DATE 4-26-02 PROJECT NO. 19125-279

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Occupied	323	69.9	21.9	509	2	16	C
C	325	70.1	21.9	516	2	16	C
IC	310	70.2	21.9	826	2	17	C
C	324	70.3	21.3	510	2	16	C
IC	312 Hall	69.9	21.6	881	2	15	C
C	316	69.9	21.9	491	2	14	C
8	318	69.6	21.9	691	2	13	C
C	320	71.1	21.9	497	2	12	C
C	322	71.3	21.6	495	2	16	C
10	NEXT TO STAIR #3 HALLWAY	71.0	21.1	977	2	16	C
	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4-26-02