

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6

Time: 1:00 PM LOCATION: PS 234

DATE: 5-9-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
OUTSIDE							
MAIN ENTRANCE	0	54.1	43.1	430	1	24	C
NEXT TO MAIN DESK	0	54.1	43.1	440	1	16	C
NORTH WEST CORNER	0	54.1	43.1	431	1	21	C
WEST SIDE	0	54.1	43.1	427	1	23	C
SOUTH WEST CORNER	0	54.1	43.1	442	1	24	C
COURT YARD	0	54.1	43.1	443	1	23	C
NORTHEAST CORNER	0	54.4	43.1	439	1	20	C
MAIN ENTRANCE	0	54.1	43.2	431	1	23	C
SOUTH EAST CORNER	0	54.4	43.1	430	1	23	C
SOUTH SIDE	0	54.1	43.1	449	1	20	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: 

Date: 5-9-02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

Time: 11:00 AM LOCATION: PS 234 DATE: 5-9-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall next to Stairwell 3	0	70.8	40.1	481	2	20	0
Rm 120	0	70.1	41.1	477	2	19	0
Rm 122	22	70.6	40.2	1119	2	16	0
Rm 222	0	70.1	39.1	477	2	19	0
Rm 220	0	71.4	40.6	461	2	20	0
218 Hall	0	71.4	40.5	452	2	19	0
Rm 216	0	71.4	39.9	410	2	20	0
Rm 212	0	71.6	39.6	421	2	16	0
Rm 224	0	72.3	38.6	422	2	16	0
Rm 229	27	72.3	41.1	1023	7	14	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-9-02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

Time: 11:15 AM LOCATION: PS 234 DATE: 5-9-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
CAFETERIA	0	72.1	40.6	488	2	18	0
HALL NEXT TO GYM	0	71.6	39.8	470	2	19	0
MAIN Foyer	0	71.6	40.1	471	2	20	0
main desk	2	71.6	41.1	510	2	21	0
NEXT TO ELEVATOR	0	71.6	40.1	490	2	15	0
HALL NEXT TO EXIT 1	0	71.8	40.3	461	2	16	0
114 HALL	0	71.6	39.9	466	2	16	0
116	17	71.5	38.2	941	2	15	0
118	21	71.6	39.7	1012	2	16	0
120	25	71.5	40.9	1121	2	17	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *[Signature]* Date: 5-9-02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6

Time: 11:40 AM LOCATION: PS 234 DATE: 5-9-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
227 Hall	0	72.1	39.6	499	2	16	0
210 Hall	0	71.6	39.9	501	2	18	0
Rm 225	20	71.1	40.6	1011	2	21	0
Rm 223	2	73.4	40.1	610	2	21	0
NEXT TO ELEVATOR BANK	0	72.1	40.7	457	2	16	0
Rm 214	0	73.4	39.9	440	2	16	0
Rm 206	0	73.6	40.1	439	2	17	0
206 Hall	0	72.6	40.3	440	2	18	0
Rm 215	0	73.9	40.4	471	2	17	0
Rm 211	28	73.7	41.0	1242	2	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *[Signature]* Date: 5-9-02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6

Time: 12:30 pm LOCATION: PS 284 DATE: 5-9-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Rm 202	16	72.3	40.1	986	2	20	0
Rm 301	3	72.1	39.8	660	2	19	0
302 Hall	0	71.1	39.7	491	2	19	0
Rm 305	18	72.4	41.1	1021	2	18	0
Rm 304	0	72.5	41.7	426	2	16	0
Rm 311	0	72.6	40.0	446	2	21	0
Rm 306	14	72.6	41.7	902	2	22	0
Rm 315	11	72.9	41.1	891	2	19	0
Rm 308	0	72.9	39.9	471	2	19	0
Rm 319	0	72.9	40.1	476	2	19	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: NP

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-9-02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

Time: 12:40 pm

LOCATION: PS 234

DATE: 5-9-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Rm 323	0	72.4	41.1	477	2	19	0
Rm 325	0	73.1	42.6	501	2	25	0
Rm 310	0	72.9	40.1	499	2	19	0
Rm 324	10	72.6	39.9	991	2	18	0
312 HALL	0	71.4	40.6	461	2	16	0
Rm 316	15	72.3	41.9	1016	2	16	0
Rm 318	0	72.4	40.3	486	2	16	0
Rm 320	9	72.6	41.6	971	2	15	0
Rm 322	0	72.7	41.3	479	2	19	0
NEXT TO STAIR H3 HALL	10	71.5	41.1	989	2	18	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-9-02