

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6

TIME 1400

LOCATION PS234M

DATE 5/15/04

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
Outside							
Air Reading							
Main Entrance		56.2	25.4	396	1	19	C.C.
Air Reading							
By Elevator (U)		60.0	30.2	440	1	13	C.C.
South		60.8	21.0	380	1	20	C.C.
SE		61.0	21.1	382	1	17	C.C.
Main Entrance		61.3	21.6	388	1	10	C.C.
NE		61.6	21.8	388	1	12	C.C.
Courtyard		61.8	21.5	388	1	16	C.C.
East		61.5	21.3	381	1	14	C.C.
West		61.1	21.9	386	1	16	C.C.
SW		60.9	22.0	381	1	19	C.C.
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/15/04

CITY_21MC100_002920521

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

TIME 1430

LOCATION PS234M

DATE 5/15/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Culinary		76.0	27.5	570	1	8	c.c.
By Line Desk		75.9	27.6	558	1	13	c.c.
Exam		74.2	26.2	735	1	20	c.c.
Hall by Exit 1		71.3	25.8	544	1	14	c.c.
114 (Hall)		70.1	25.0	470	1	15	c.c.
116	1	70.5	25.6	504	1	16	c.c.
116 (Hall)		70.3	25.6	460	1	14	c.c.
118		69.2	25.1	430	1	16	c.c.
120	27	70.7	24.9	870	1	26	c.c.
123	23	69.8	27.1	512	1	18	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/15/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1


TIME 1500

LOCATION PS234M DATE 5/15/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
214 (Hall)		69.7	26.6	476	1	15	0.0
222 (Hall)		70.8	31.6	500	1	7	0.0
223		71.7	31.4	743	1	7	0.0
226		72.7	32.3	773	1	7	0.0
218		73.5	22.1	796	1	8	0.0
216 (Hall)		73.3	31.7	777	1	6	0.0
212 (Hall)		73.2	31.8	774	1	7	0.0
229		73.6	32.7	743	1	7	0.0
227 (Hall)		73.5	31.6	789	1	9	0.0
225		73.0	31.5	785	1	8	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/15/02

CITY_21MC100_002920523

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2

TIME 1530

LOCATION PS234M


DATE 5/15/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
210 (room)		73.8	30.1	740	1	11	C.C.
213 (room)		73.9	29.6	730	1	11	C.C.
214		73.9	29.9	702	1	12	C.C.
Hall by Elevator		74.0	29.0	715	1	9	C.C.
206		73.8	29.2	674	1	10	C.C.
215 (room)		74.1	28.0	680	1	9	C.C.
211		74.3	29.9	750	1	10	C.C.
206 (room)		74.3	29.6	718	1	9	C.C.
Stair 2 (room)		74.0	27.5	671	1	13	C.C.
201		73.1	26.8	625	1	10	C.C.
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/15/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6

TIME 1600

LOCATION PS234M

DATE 5/15/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
301		74.2	30.6	728	1	10	0.0
302 (Hall)		74.5	30.7	757	1	13	0.0
303 (Hall)		74.4	30.3	734	1	16	0.0
305		74.8	31.3	830	1	14	0.0
304		74.7	30.7	790	1	24	0.0
306		73.6	34.3	817	1	2	0.0
315		73.2	30.1	824	1	17	0.0
308		74.7	31.6	736	1	16	0.0
314		74.3	31.2	809	1	14	0.0
321 (Hall)		73.2	24.8	816	1	24	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/15/02

CITY_21MC100_002920525

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2

TIME 10:30

LOCATION PS/IS89M

DATE 5/15/02

PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
323		73.5	30.4	814	1	10	
324 (Hall)		73.2	30.8	719	1	14	
310		73.0	29.8	812	1	8	0.5
325		73.2	31.0	840	1	10	0.5
327 (Hall)		73.1	30.6	721	1	12	0.5
329		72.3	28.7	747	1	11	0.5
316		72.0	29.4	736	1	14	0.5
318 318		73.1	30.1	753	1	8	0.5
320		73.3	30.3	690	1	10	0.5
329		72.8	29.8	795	1	6	0.5
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

5/15/02