


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 8:10LOCATION PS89 M DATE 3/5/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Playground North		32.0	13.1	487	0	23	0
Playground South			13.3	490	0	25	0
NE Corner Outside			13.5	485	0	29	0
North Exit Outside			13.9	480	0	24	0
NW Corner Outside			13.6	483	0	20	0
By Intake Outside			13.3	486	0	23	0
SW Corner Outside			13.7	480	0	22	0
South Exit Outside			14.0	478	0	23	0
SE Corner Outside			14.3	481	0	25	0
East Side Outside			14.1	486	0	23	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Instrument Stopped on 32° (Q-Trak)

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923223

ATC ASSOCIATES, INC.


Page 2 of 8TIME 8:35

INDOOR AIR QUALITY FIELD REPORT

LOCATION P589 M DATE 3/5/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
132A	1	69.1	13.6	635	0	16	0
132B	-	69.3	12.6	579	0	18	0
132C	-	69.3	12.7	579	0	16	0
132D	-	69.2	13.1	590	0	17	0
Hall by Stair 1	-	69.2	11.8	608	0	27	0
North Exit Inside	-	70.0	12.4	678	0	24	0
Hall by Cafeteria	-	70.3	11.1	635	0	23	0
Cafeteria	15	69.4	11.7	729	0	17	0
Hall by Elevator	-	69.8	11.4	654	0	20	0
South Exit Inside	-	70.4	10.8		0	21	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/5/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 9:00LOCATION PS89 M DATE 3/5/02 PROJECT NO. 19125-297

Location	Occup. m	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
502	1	71.2	10.9	607	0	18	0
501 (Hall)	-	70.8	11.4	605	0	16	0
Stair 3 (Hall)	-	71.2	10.7	614	0	19	0
504	32	72.0	14.3	949	0	21	0
Hall by Elevator.	-	72.1	11.7	720	0	19	0
506	28	72.0	13.9	1109	0	19	0
515	1	71.9	12.1	654	0	20	0
509 (Hall)	-	71.8	11.8	606	0	18	0
508	-	71.2	11.0	580	0	18	0
510 (Hall)	-	71.5	10.7	582	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923225

ATC ASSOCIATES, INC.

Page 4 of 8

INDOOR AIR QUALITY FIELD REPORT

TIME 930LOCATION P589 MDATE 3/5/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
526	1	71.0	10.7	640	0	19	0
528	28	70.4	12.3	698	0	18	0
530 (Hall)	—	70.3	11.0	632	0	17	0
517	1	70.4	10.3	589	0	15	0
532	33	70.7	12.7	975	0	17	0
Stair 1 (Hall)	—	70.9	12.1	772	0	17	0
Stair 1	—	70.5	11.3	675	0	17	0
419	3	70.9	11.4	616	0	15	0
432	2	71.4	12.6	586	0	15	0
419 (Hall)	—	71.6	12.1	599	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923226

ATC ASSOCIATES, INC.

Page 5 of 8

TIME 1000
030


INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89M DATE 3/5/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
430	-	71.3	12.3	627	0	11	0
426	15	71.3	13.2	907	0	19	0
Stair 2 (Hall)	-	71.3	12.1	780	0	18	0
Stair 2	-	71.2	11.2	640	0	17	0
410 (Hall)	-	71.5	10.8	608	0	18	0
408	32	70.7	13.6	1115	0	16	0
406 (Hall)	-	71.0	11.0	654	0	18	0
404	34	71.5	12.1	946	0	21	0
401	17	70.3	12.2	757	0	14	0
402	1	68.8	10.6	593	0	20	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923227

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8

TIME 1030

LOCATION P589 M


DATE 3/5/02

PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301	25	70.8	12.5	739	0	14	0
302 (Hall)	—	70.6	11.8	680	0	18	0
302	—	72.5	10.4	605	0	17	0
304	3	71.8	10.3	629	0	18	0
Hall by Elevator	—	71.2	10.3	613	0	19	0
306	1	70.2	10.3	604	0	18	0
Gym	42	69.5	11.5	675	0	18	0
308	1	67.8 ✓	11.5	670	0	20	0
310	3	68.2	11.6	655	0	18	0
316	—	69.2	10.8	612	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923228

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8


TIME 1100

LOCATION PS89 M DATE 3/5/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
326	16	70.5	11.2	690	0	17	0
328 (Hall)	—	70.2	10.9	640	0	19	0
330	—	70.6	11.9	681	0	18	0
332	17	70.3	11.3	589	0	14	0
319 (Hall)	—	70.2	10.9	637	0	20	0
219	2	71.0	10.8	650	0	18	0
232	1	71.0	11.9	762	0	16	0
230	1	70.7	12.0	722	0	19	0
217C (Hall)	—	70.7	11.2	683	0	19	0
228	12	71.2	12.5	794	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923229


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION PS89 M DATE 3/5/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
226	-	70.6	10.7	639	0	19	0
Stair 2 (Hall)	-	70.5	10.1	621	0	19	0
208 (Hall)	-	70.0	9.7	604	0	18	0
Auditorium	35	69.4	9.6	629	0	18	0
206 (Hall)	-	69.9	9.5	613	0	18	0
204	1	70.1	10.1	609	0	18	0
Hall by Elevator	-	70.1	10.3	628	0	18	0
201	-	69.7	10.6	640	0	13	0
202	3	69.5	10.6	618	0	18	0
202 (Hall)	-	70.0	10.1	625	0	19	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002923230