

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION : STUYVESANT HIGH SCHOOL DATE 02-6-02 PROJECT NO. 15-19125-0246

RESPIRABLE PARTICULATES ($\mu\text{g} / \text{m}^3$)
In Rooms with portable HEPA air Purifier

Time /Location	Room 740	Room 638	Room 333	Room 327
7:50	15	16	14	17
9:30	16	17	16	19
10:20	17	17	15	18
11:10	18	16	16	19
12:10	18	18	16	18
13:05	17	17	15	18