

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 3/13/02 8:45:00 PM
ATC Group #: 7061
Analysis Date: 3/13/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 7061 -1	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
04 7061 -2	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
05 7061 -3	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
06 7061 -4	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 7061 -5	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
08 7061 -6	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
09 7061 -7	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 3/13/02 8:45:00 PM
ATC Group #: 7061
Analysis Date: 3/13/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
10 7061 -8	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 7061 -9	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 7061 -10	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 7061 -11	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 7061 -12	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 7061 -13	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 7061 -14	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 7061 -15	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 7061 -16	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 3/13/02 8:45:00 PM
ATC Group #: 7061
Analysis Date: 3/13/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	5μ		(S/mm ²)	(S/cc)	
19 7061 -17	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879