

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/1/02 9:10:00 PM
 ATC Group #: 7602
 Analysis Date: 5/1/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance
 100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 7602 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 7602 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 7602 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
06 7602 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 7602 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
08 7602 -6	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
09 7602 -7	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 2

CITY_21MC100_002901560