

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/12/02 6:00:00 PM
 ATC Group #: 7723
 Analysis Date: 5/12/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
03 7723 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
04 7723 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
05 7723 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
06 7723 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
07 7723 -5	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7723 -6	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 7723 -7	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10379

Page 1 of 3

CITY_21MC100_002901823

Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: H.S. Of Economics And Finance

Received: 5/12/02

6:00:00 PM

ATC Group #: 7723


Analysis Date: 5/12/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
10 7723 -8	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
11 7723 -9	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
12 7723 -10	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 7723 -11	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 7723 -12	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 7723 -13	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 7723 -14	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
17 7723 -15	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
18 7723 -16	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Page 2 of 3

CITY_21MC100_002901824

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/12/02 6:00:00 PM
 ATC Group #: 7723
 Analysis Date: 5/12/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
19 7723 -17	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 3 of 3

CITY_21MC100_002901825