NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 05-02-02

CLIENT: NYC BOE

PROJECT ADDRESS: Stuyvesant HS (M477)/345 Chambers St.
NY, NY 10007

PROJECT NO: 19125-0246
SAMPLED BY: H. Antonyan

SAMPLE DATE: 05-01-02
DATE RECEIVED: 05-01-02
DATE ANALYZED: 05-01-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
01	9793	5th Floor Cafeteria Floor	<9.0	9.0
02	9793	5th Floor Cafeteria Window Sill	<4.5	4.5
03	9793	3rd Floor Aux. GYM Floor	<9.0	9.0
04	9793	3rd Floor Aux. GYM Window Sill	<18.0	18.0
05	9793	1st Floor Pool Area Floor	<9.0	9.0
06	9793	1st Floor Pool Area Window Sill	22.1	4.7
07	9793	Auditorium Floor	<9.0	9.0
08	9793	1st Floor Lobby Area Floor	<9.0	9.0
09	9793	2nd Floor Lobby Area Floor	<9.0	9.0
10	9793	7th Floor Hallwya Middle Floor	<9.0	9.0
11	9793	6th Floor Hallway Middle Floor	<9.0	9.0
12	9793	Rm 638 N. Floor	<9.0	9.0
13	9793	Rm 638 N. Window Sill	<3.6	3.6

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

14	9793	Rm 507 S. Floor	<9.0	9.0
15	9793	Rm 507 S. Window Sill	<5.4	5.4
16	9793	Rm 401 E. Floor	<9.0	9.0
17	9793	Rm 401 E. Window Sill	<5.4	5.4
18	9793	Blank	<9.0 µg	9.0 µg
19	9793	Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).