

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 05-08-02
CLIENT: NYC BOE
PROJECT ADDRESS: Stuyvesant HS (M477)/345 Chambers St.
NY, NY 10007
PROJECT NO: 19125-0246
SAMPLED BY: H. Antonyan
SAMPLE DATE: 05-08-02
DATE RECEIVED: 05-08-02
DATE ANALYZED: 05-08-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9806	5th Floor Cafeteria Floor	<9.0	9.0
02	9806	5th Floor Cafeteria Window Sill	<4.5	4.5
03	9806	3rd Floor Aux. GYM Floor	<9.0	9.0
04	9806	3rd Floor Aux. GYM Window Sill	<18.0	18.0
05	9806	1st Floor Pool Area Floor	<9.0	9.0
06	9806	1st Floor Pool Area Window Sill	<4.7	4.7
07	9806	Auditorium Floor	<9.0	9.0
08	9806	1st Floor Lobby Area Floor	<9.0	9.0
09	9806	2nd Floor Lobby Area Floor	<9.0	9.0
10	9806	3rd Floor Hallway Middle Floor	<9.0	9.0
11	9806	2nd Floor Hallway Middle Floor	<9.0	9.0
12	9806	Rm 507 S. Floor	<9.0	9.0
13	9806	Rm 507 S. Window Sill	<5.4	5.4

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

14	9806	Rm 401 E. Floor	<9.0	9.0
15	9806	Rm 401 E. Window Sill	<5.4	5.4
16	9806	Rm 351 N. Floor	<9.0	9.0
17	9806	Rm 351 N. Window Sill	<6.5	6.5
18	9806	Blank	<9.0 µg	9.0 µg
19	9806	Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).