



MORETRENCH AMERICAN CORPORATION

www.moretrench.com

June 11, 2002

Serial Letter 01-4906-126

100 Stickle Avenue
P.O. Box 316
Rockaway, N.J. 07866
Tel: (973) 627-2100
Fax: (973) 627-3950 / 627-6078

VIA FACSIMILE (3 wfc)
(212) 640-9202

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
200 Park Avenue
New York, NY 10166

Total # of Pages:

13

RE: World Trade Center Dewatering
Contract No. 20020004649
MTA Job 01-4906
Water Analyses

Dear Brian:

Attached find results of the analysis of the water samples taken from the WTC site on May 28, 2002. MTBE level for the sump discharge (B-6 30 hp sump pump) was 34 ppb and for the dewatering walls (Greenwich Street) was 0.3 (undetected) ppb.

Chlorodifluoromethane was 65 ppb in the sump discharge and 1.0 (undetected) ppb in the Greenwich Street dewatering well discharge.

Results of water samples tested for dioxin and asbestos taken on May 28, 2002 are also included. Sample ID # 352812 is taken from the Greenwich Street dewatering well discharge and Sample ID # 352813 is taken from the sump discharge and.

We are also forwarding a copy of the tables which track MTBE and Chlorodifluoromethane concentrations for all of the water sample testing which has been performed on the site.

Very truly yours,
MORETRENCH AMERICAN CORPORATION

John F. Donohoe
President

cc: Billy Klingler, MTA

010/1001

MORETRENCH AMERICAN

06/11/2002 15:51 FAX 973 627 3950

CONFIDENTIAL,

CITY_21MC100_003477863

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000229593