



KAM CONSULTANTS
 35-40 36th Street
 Long Island City
 New York, 11106
 Tel: (718) 729-1997
 Fax: (718) 729-1876

ANALYSIS REPORT
ASBESTOS IN AIR
Transmission Electron Microscopy

CLIENT: Department of Design and Construction - 30-30 Thomson Avenue, Long Island City, NY 11101
PROJECT ADDRESS: Stuyvesant H.S., 345 Chambers St., NY, NY 10282 Pier #25

Lab ID#	Client Sample ID#	Sample Location	Volume (liters)	Grid Openings Examined	Filter Area (mm ²)	Analytical Sensitivity (struc/cc air)	Asbestos Type(s)	Asbestos Structures (microns)		Detected Total	Structure Density (struc/mm ²) Total	Structure Concentration (struc/cc) Total
								0.5-5.0	>5.0			
T020210A-01	1	North Exit of Stuyvesant H.S.	1800	6	385	0.0043	ND	0	0	0	<20.00	<0.0043
T020210A-02	2	North West Site	1800	6	385	0.0043	ND	0	0	0	<20.00	<0.0043

Area Analyzed: 0.0600 mm²
 Grid Opening Area: 0.010 mm²
 Date Collected: 02/09/02(07:00-17:00)

Date Received: 02/10/02
 Date Analyzed: 02/10/02
 Date of Report: 02/11/02

Analyst: AB
 Alex Barengolts

Lab Manager: DC
 David Chen

Analysis performed according to AHERA Method (EPA 40 CFR Part 763 - Appendix A). Samples will be stored for ninety (90) days and then returned to the client upon request.
 Sample volume is below recommended limit of the method
 AIHA #: 100269

NIST-NVILAP #: 102047

NYS-DOH ELAP#: 11273

CONFIDENTIAL,
 SUBJECT TO PROTECTIVE ORDER NO.3, JULY 2009
 CITY_21MC100_011815823