



Environmental Laboratory
47 Hudson Street, Ossining, New York 10562

CONFIDENTIAL

NYS ELAP # 11142
NYLAP # 200083-0
NHA # 100147

Transmission Electron Microscopy Results

Client: Bovis Lend Lease
200 Park Avenue
New York, New York

Project #: MBO-025AE

Sample Location: The Millenium Hilton Hotel
55 Church Street
New York, New York

Date Collected: 09/30/01
Date Rec'd (lab): 10/01/01
Analysis Date: 10/08/01
TEM Analyst: D. McCarl
Analytical Method: AHERA
EPA 40 CFR Part 763

Field Technician: M. Sokolinskiy/O. Kolendekov

Filter Type - MCE 0.45 micron
Avg. Grid Opening: 0.0121mm²

Sample #:	Sample Location:	Lab Number 01TEM #	Volume Coll. (liters)	Grid Openings Analyzed	Grid Area Analyzed	Countable Asb. Structures	Concentration Structures/mm ²	Concentration Structures/cc
19-1	South Side of Corridor	3508	1250.0	6	0.073	10	137.74 ✓	0.042
19-2	In the Middle of Corridor	3509	1250.0	6	0.073	7	96.42 ✓	0.030
19-3	North Side of Corridor	3510	1250.0	6	0.073	1	13.77	0.004
18-1	South Side of Corridor	3511	1250.0	6	0.073	8	110.19 ✓	0.034
18-2	In the Middle of Corridor	3512	1250.0	6	0.073	5	68.87	0.021
18-3	North Side of Corridor	3513	1250.0	6	0.073	5	68.87	0.021
14-1	South Side of Corridor	3514	1250.0	6	0.073	9	123.97 ✓	0.038
14-2	In the Middle of Corridor	3515	1250.0	6	0.073	17	234.16 ✓	0.072
14-3	North Side of Corridor	3516	1250.0	6	0.073	15	206.61 ✓	0.064
12-1	South Side of Corridor	3517	1250.0	6	0.073	5	68.87	0.021
12-2	In the Middle of Corridor	3518	1250.0	6	0.073	6	82.64 ✓	0.025
12-3	North Side of Corridor	3519	1250.0	6	0.073	4	55.10	0.017
Total Average Concentrations							Structures/mm ² 105.60	Structures/cc <0.032

This report is the confidential property of our clients. This certificate of analysis/report shall not be used by the client to claim product endorsement by the National Voluntary Laboratory Approval Program (NVLAP) or any agency of the United States Government. The laboratory has no control over air sampling collection. This certificate of analysis/report shall not be reproduced in full, without the written approval of Testwell Laboratories, Inc.

Copyright © 2001 Testwell Laboratories, Inc.

D. McCarl
Laboratory Director/Approved Signatory