



Environmental Laboratory
47 Hudson Street, Ossining, New York 10562

NYS ELAP # 11142
NVLAP # 200083-0
AHERA # 100147

CONFIDENTIAL

Transmission Electron Microscopy Results

Client: Bovis Lend Lease
200 Park Avenue
New York, New York

Project #: MBO-025AB

Sample Location: The Millenium Hilton Hotel
55 Church Street
New York, New York

Date Collected: 09/30/01
Date Rec'd (lab): 10/01/01
Analysis Date: 10/08/01
TEM Analyst: D. McCarl
Analytical Method: AHERA
EPA 40 CFR Part 763

Field Technician: M. Sokolonskiy/O. Kolendenkov

Filter Type - MCE 0.45 micron
Avg. Grid Opening: 0.0121mm²

Sample #:	Sample Location:	Lab Number 01TEM #	Volume Coll. (liters)	Grid Openings Analyzed	Grid Area Analyzed	Countable Asb. Structures	Concentration Structures/mm ²	Concentration Structures/cc
11-1	South Side of Corridor	3520	1250.0	6	0.073	19	261.71 ✓	0.081
11-2	In the Middle of Corridor	3521	1250.0	6	0.073	12	165.29 ✓	0.051
11-3	North Side of Corridor	3522	1250.0	6	0.073	14	192.84 ✓	0.059
10-1	South Side of Corridor	3523	1250.0	6	0.073	3	41.32	0.013
10-2	In the Middle of Corridor	3524	1250.0	6	0.073	2	27.55	0.008
10-3	North Side of Corridor	3525	1250.0	6	0.073	18	247.93 ✓	0.076
9-1	South Side of Corridor	3526	1250.0	6	0.073	13	179.06 ✓	0.055
9-2	In the Middle of Corridor	3527	1250.0	6	0.073	12	165.29 ✓	0.051
9-3	North Side of Corridor	3528	1250.0	6	0.073	11	151.52 ✓	0.047
4-1	South Side of Corridor	3529	1250.0	6	0.073	4	55.10	0.017
4-2	In the Middle of Corridor	3530	1250.0	6	0.073	11	151.52 ✓	0.047
4-3	North Side of Corridor	3531	1250.0	6	0.073	2	27.55	0.008
Total Average Concentrations							Structures/mm ² 138.89	Structures/cc 0.04

This report is the confidential property of our clients. This certificate of analysis/report shall not be used by the client to claim product endorsement by the National Voluntary Laboratory Approval Program (NVLAP) or any agency of the United States Government. The laboratory has no control over air sampling collection. This certificate of analysis/report shall not be reproduced in full, without the written approval of Testwell Laboratories, Inc.

Copyright © 2001 Testwell Laboratories, Inc.

D. McCarl
Laboratory Director/Approved Signatory