

FESTWELL LABORATORIES, INC.

17 Hudson Street, Ossining, N.Y. 10562

TEL (914) 944-2570 FAX (914) 941-4154

Air Sample Data Chain of Custody Page 1 of 1Client: **BOVIS LEND LEASE - LMB**Project Site: **MILLENNIUM HILTON HOTEL @ WTC, VARIOUS FLOORS**Project Address: **55 CHURCH STREET, NEW YORK, NY 10007**Report to: **MICHAEL DEANE** **BOVIS** (212) 592-6964 (FAX)

Name

Company

Tel/Fax

Date Analyzed: 7/30/02 Analyst: [Signature]

TEL FIELD OFFICE FAX:- (212) 312-2147 (FAX)

Project #: **MB0 - 025 AB**Date: 07.29.02Technician: B. GitmanSignature: [Signature]Rotometer: R 0901

TURNAROUND TIME:

ANALYSIS: LABORATORY USE ONLY: PC

FIELD SAMPLE #	SAMPLE TYPE	SAMPLE LOCATION	PUMP#	START TIME	STOP TIME	TOTAL MINUTES	FLOW RATE START/STOP	TOTAL VOLUME	PCM # TEM #	FIBERS/ FIELDS	RESULTS 1/cc 1/3/cc	RESULTS 1/min 1/5/min
1091	4	Person Decor		1350	1800	250	5/5	1250	23203	9.5/100	0.0039	
1092		Waste Decor		1350	1800	250	5/5	1250	23204	12.1/100	0.0043	
1093		3 rd floor kitchen inside air loc		1400	1800	245	5/5	1225	23205	6.1/100	0.0025	
1094	✓	↓ out side air loc		1400	1800	245	5/5	1225	23206	5.1/100	0.0023	
1095	4	Person Decor		1800	2230	270	5/5	1350	23207	6.9/100	0.0027	
1096		Waste Decor		1800	2230	270	5/5	1350	23208	7.1/100	0.0029	
1097		3 rd floor kitchen inside air loc		1800	2215	250	5/5	1250	23209	5.1/100	0.0023	
1098	✓	↓ out side air loc		1800	2215	250	5/5	1250	23210	12.1/100	0.0023	
1099		Blow's					-	-	23211	0.1/100	-	
1100		Blow's					-	-	23212	0.1/100	-	
										1		
										1		

Inquired by (signature):

Date/Time:

Received by (signature):

Date/Time:

SAMPLE 1 - Ambient 2 - Background 3 - Pre-Test

CODES: 4 - During 5 - Final 6 - Personal/OSHA

IWA: INSIDE WORK AREA

CITY_21MC100_011963130