

Summary of Asbestos Sampling Results

Page 1 of 2

Address: 49 Fulton St

Date sampled: Nov 29, 2001

Dust samples

Fibrous materials in dust found by Polarized Light Microscopy (PLM) Analysis: Polarized Light Microscopy identifies asbestos fibers by shape and optical characteristics. Other fibers such as fabric (synthetics), paper (cellulose) and fiberglass may be identified in the analysis. The laboratory analyst counts the fibers present to give an estimate of fiber content as a percent.

Area Sampled	Outside	Common	Residence 1	Residence 2
Sample Numbers	No Dust Available	VA-C-23	VA-R1-23	VA-R2-23
Asbestos present in dust: Chrysotile asbestos	No Dust Available	None Detected	None Detected	None Detected

Asbestos in dust as determined by Transmission Electron Microscope (TEM) Analysis: TEM analysis was conducted on all dust samples, which showed asbestos content, by PLM as less than 1%. TEM analysis is very specific, can detect smaller fibers of asbestos and is sensitive to fewer interferences. This analysis was done to confirm the PLM findings of no asbestos shown above.

Area Sampled	Outside	Common	Residence 1	Residence 2
Sample Numbers	No Dust Available	VA-C-23	VA-R1-23	VA-R2-23
Asbestos present in dust: Chrysotile	No Dust Available	None Detected	None Detected	None Detected

J:\Summary of Asbestos Sampling Results.doc

Feb. 22 2002 03:15PM PLS

PHONE NO. : 2125711634

FROM : ST. MARGARET'S HOUSE

CONFIDENTIAL,

CITY_21MC100_003384785

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Summary of Asbestos Sampling Results**Page 2 of 2**

Address: 49 Fulton St
 Date sampled: Nov 29, 2001

Air samples

Airborne fibers as determined by Phased Contrast Microscopy (PCM): An air sample is collected by pulling air through a filter. The filter catches fibers and is then sent to a laboratory to determine what types of fibers were in the air. Phase contrast microscopy identifies fibers based on size and shape, but not mineral composition. Therefore, the fibers seen by PCM include asbestos fibers as well as other fibers, such as textiles, fiberglass, cellulose, which might be present in your home.

Area Sampled	Outside	Common	Residence 1	Residence 2
Sample Numbers	A-O-23	A-C-23	A-R1-23	A-R2-23
Concentration of Fibers in Air at this location	<.001	<.001	<.001	<.001
Concentration of Fibers in Air at background locations	<.001	<.001 to .003	<.001 to .003	<.001 to .003
Screening Value**	.01 f/cc	.01 f/cc	.01 f/cc	.01 f/cc

**Screening Value – The NYC standard for asbestos in community and residential buildings is 0.01 fibers/cubic centimeter (f/cc) in indoor air. This standard is used for re-occupancy in an indoor area where asbestos was detected and removed.

J:\Summary of Asbestos Sampling Results.doc

Feb. 22 2002 03:15PM P16

PHONE NO. : 2125711634

FROM : ST. MARGARET'S HOUSE

CONFIDENTIAL,

CITY_21MC100_003384786

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008