

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Joshua Sarent
ALC Environmental

115 W. 30th Street

New York NY 10001

Fax: (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
395 Southard Ave., Bldg 600, New York, NY

Received: 12/18/01 8:00:00 AM

ATC Group #: 6128

Analysis Date: 12/18/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
D-1 6128 -1	1800.00	0.0450	0	CHRYSTOLE	0	1	0.0048	22.24	0.0048
D-2 6128 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
D-3 6128 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
D-4 6128 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
D-5 6128 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
D-6 6128 -6	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by: *RRig*

MICHAEL A. GORYCKI, Ph.D.

Approved by:


Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003385244

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008



The First Choice for Environmental Testing & Consulting

Client: City of New York Date: 12-17-01
 Sampled By: Donald Scholtz Rotometer #: 12-17-01 Project #: 2707
 Work Area: 100 395 South End Ave.

Sample # Lab #	Sample Location	Code	Time		Total Minutes	Flow Rate		Total Volume	# Fibers /100 Fields	Results (l/cc)
			Start	Stop		Start	Stop			
D-1	Apt # 26-P Inside FOYER	3	1815	2115	180	10.0	10.0	1800		
D-2	Apt # 26-P Inside KITCHEN	3	1816	2116	180	10.0	10.0	1800		
D-3	Apt # 26-P Inside LIVING ROOM	3	1817	2117	180	10.0	10.0	1800		
D-4	26th Floor Hallway E. WALL	3	1818	2118	180	10.0	10.0	1800		
D-5	26th Floor Hallway W. WALL	3	1819	2119	180	10.0	10.0	1800		
D-6	26th Floor Hallway M. WALL	3	1920	2120	180	10.0	10.0	1800		
D-7	Field Blank									
D-8	Field Blank									
D-9	Sealed Blank									

Codes: 1. Pre-Test 2. Project 3. Final 4. Investigative 5. Personal 6. During 7. Aggressive 8. Excursion 9. TWA

Analysis: ☒ TEM AHRA ☐ TEM Philadelphia ☐ PCMA MOSH 7400 ☐ ASAP ☐ 2 Day (48hr) ☒ Remote Dry (12hr)

Relinquished: Blaine Scholtz Date: 12-18-01 Received: ATC Date/Time: 12/18/01
 Analyst: ATC-TEM By: ATC Disposal By/Date: ATC 12/18/01

115 West 30th Street • 11th Floor • New York, New York 10001 • 212 279 1001 • 888 466 3620 • Fax: 212 279 6747
 Home Office: The Bellevue • Suite 600 • 200 S. Broad Street • Philadelphia, PA 19102 • 215 732 9499 • 888 789 8378 • Fax: 215 732 9559
 www.ATCEnvironmental.com

CONFIDENTIAL,

CITY_21MC100_003385245

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008