

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 04-11-02

CLIENT: NYC BOE

PROJECT ADDRESS: (M894)/90 Trinity Place
NY, NY 10006

PROJECT NO: 41717-0561
SAMPLED BY: Y. Efstathiou

SAMPLE DATE: 04-11-02
DATE RECEIVED: 04-11-02
DATE ANALYZED: 04-11-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9756	Blank	<9.0 μg	9.0 μg
02	9756	1st Floor Lobby (Floor)	<9.0	9.0
03	9756	Auditorium Floor	<9.0	9.0
04	9756	3rd Floor Hallway Floor	<9.0	9.0
05	9756	5th Floor Hallway Floor	<9.0	9.0
06	9756	7th Floor Hallway Floor	<9.0	9.0
07	9756	9th Floor Hallway Floor	<9.0	9.0
08	9756	13th Floor Hallway Floor	<9.0	9.0
09	9756	Cafeteria Floor	9.3	9.0
10	9756	Cafeteria #906 Floor	<9.0	9.0
11	9756	Classroom #503 Window Sill	<7.9	7.9

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CONFIDENTIAL,

CITY_21MC100_003387908

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: *TL*

REPORT PREPARED BY: *[Signature]*

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: *[Signature]*

LABORATORY DIRECTOR: *[Signature]*

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).

CONFIDENTIAL,

CITY_21MC100_003387909

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008