



104 East 25th St., 10th Floor
 New York, New York 10010
 www.atc-enviro.com
 212.353.8280
 Fax 212.353.8306

April 16, 2002

Mr. Bernard P. Orlan
 New York City Board of Education
 Director, Environmental Health & Safety Unit
 28-11 Queens Plaza North
 Long Island City, NY 11101

Re: Limited settled dust bulk sampling for fiberglass at P.S. 150M

Dear Mr. Orlan:

At your request, ATC Associates, Inc. representative Mr. Mark Nakhumovich visited P.S. 150M located at 334 Greenwich Street, New York, NY 10013 on April 15, 2002. The purpose of the site visit was to perform a settled dust bulk sampling to be analyzed for fiberglass fiber content on areas indicated to ATC by ENVIRON Corp. the Parents Association environmental consultant and approved by New York City Board of Education (NYC-BOE). These areas are the following:

- 1st Floor Lobby
- Multipurpose room
- Two random classrooms

The purpose of the dust bulk sampling is to determine if settled dust in the school contains fiberglass fibers. ATC will be repeating this sampling preferably every Monday as per the recommendation of ENVIRON and after the approval of NYC-BOE. This is the 13th consecutive week such a sampling is performed in P.S. 150M.

As per your request, a total of four (4) settled dust bulk samples were collected from the aforementioned areas and were analyzed utilizing Polarized Light Microscopy (PLM).

Analytical results indicated that none of the four (4) collected settled dust bulk samples contain fiberglass fibers.

The settled dust bulk sampling performed was limited to testing for fiberglass in locations indicated by ENVIRON and as outlined in the school's BOE approved sampling protocol.

CONFIDENTIAL,

CITY_21MC100_003385940

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008


Attached please find the following:

- Settled dust bulk sample chain of custody form and laboratory results
- Laboratory and personnel certificates

If you have any questions or require additional information regarding this limited settled dust bulk sampling, please do not hesitate to contact me at (212) 353-8280 extension #211.

Sincerely,

ATC Associates, Inc.

A handwritten signature in black ink, appearing to read "Yiannis Efstathiou".

Yiannis Efstathiou
Senior Project Manager

Cc: Mr. T. Fusillo (ENVIRON Corp.)
Ms. C. Procter (UFT)
Mr. C. D'Andrea (NYC-DOH)

CONFIDENTIAL,

CITY_21MC100_003385941

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008