

ATC ASSOCIATES, INC.

Page 1 of 4TIME 1400

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 3/22/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
Top of Stairs - North Side		32.0	10.0	380	0	21	0
North Side		32.0	9.8	388	0	23	0
NW Corner		32.0	10.3	396	0	20	0
West Side		32.0	9.6	403	0	22	0
South Side		32.0	10.3	409	0	24	0
SE Corner		32.0	10.6	419	0	19	0
East Side		32.0	11.0	425	0	25	0
NE Corner		32.0	11.3	436	0	18	0
Top of Stair East Side		32.0	11.9	444	0	20	0
Main Entrance		32.0	12.4	449	0	22	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working in Courtyard

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Ji ChyDate: 3/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386175

ATC ASSOCIATES, INC.

Page 2 of 4TIME 1430

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 3/22/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Desk		75.3	16.0	438	0	12	0
Main Foyer	3	75.8	15.3	579	0	15	0
Hall by West Stairs		75.5	15.0	591	0	14	0
Ed's Room		73.9	14.8	506	0	14	0
Main Lobby		73.7	14.4	557	0	16	0
Principal Office		74.3	14.1	505	0	13	0
Main Office	3	74.8	14.5	579	0	15	0
Guidance Rm		74.6	14.6	548	0	13	0
By Boys Rm		74.7	14.5	500	1	15	0
By Girls Rm		74.6	14.4	502	1	13	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 3/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386176

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1500LOCATION PS150 MDATE 3/22/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Slopsink		75.7	15.3	578	0	16	0
Resource Rm	1	76.0	15.9	639	0	20	0
Nurse Rm		76.2	15.5	631	1	20	0
Kitchen Area		76.6	16.0	609	1	19	0
Music Rm	20	77.1	17.1	853	1	23	0
Hall by East Stair		77.0	15.1	575	1	13	0
404		76.5	14.9	503	1	13	0
404 (Hall)		76.6	15.1	526	1	13	0
403		75.6	16.9	571	1	12	0
Hall by Boys		76.3	16.3	584	1	14	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Choy Date: 3/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386177

ATC ASSOCIATES, INC.

Page 4 of 4TIME 1535

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 3/22/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
402		76.2	14.8	675	0	12	0
402 (Hall)		76.1	14.8	681	1	15	0
401		76.4	16.9	919	0	15	0
501		73.0	15.4	716	1	15	0
502		73.8	15.6	699	1	13	0
Staff Room (Hall)		74.2	15.8	677	1	16	0
Boys Rm (Hall)		74.4	15.5	635	1	15	0
503		74.7	15.7	661	1	18	0
503 (Hall)		74.1	16.4	717	1	16	0
504	1	75.1	18.0	801	1	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Jim A

Date: _____

3/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386178