

ATC ASSOCIATES, INC.

Page 1 of 4TIME 1400

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 3/11/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
South Outside		36.1	17.0	365	0	20	0
SE Corner Outside		36.3	17.3	369	0	18	0
East Side Outside		36.8	16.9	371	0	22	0
NE Corner Outside		37.3	16.5	370	0	23	0
North Outside		37.0	17.0	365	0	20	0
NW Corner Outside		36.8	17.5	369	0	19	0
West Outside		37.3	18.1	375	0	24	0
Top of Stair North Side Outside		37.6	16.3	381	0	21	0
Top of Stairs. East Outside		37.4	16.0	383	0	23	0
Outside Main Entrance		37.0	15.8	378	0	19	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 3/11/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386233

ATC ASSOCIATES, INC.

Page 2 of 4TIME 1425

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 3/11/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		70.0	15.0	489	0	12	0
Hall by West Stairs		69.8	14.6	500	0	13	0
Main Desk		71.6	14.0	503	0	10	0
Main Lobby Area		72.3	14.3	519	0	9	0
Ed's Room		73.8	13.8	529	0	8	0
Main Office		74.0	14.0	509	0	11	0
Principal Office		74.3	13.6	490	0	10	0
Guidance Rm.		74.0	13.8	486	0	9	0
Hall by Boys Rm.		74.8	14.3	509	0	12	0
Hall by Girls Rm.		74.6	14.5	515	0	11	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/11/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386234


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1450LOCATION PS150 MDATE 3/11/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource Rm		74.1	13.8	509	0	10	0
Nurse Rm		74.3	14.6	529	0	13	0
Kitchen Area		75.6	17.8	538	0	9	0
Hall by Slopsink		74.0	16.9	499	0	15	0
Music Room		74.3	16.6	609	0	8	0
Hall by East Stairs		74.8	17.0	515	0	12	0
East Stairs		73.6	17.3	491	0	16	0
404		73.2	16.5	601	0	9	0
403		72.9	16.0	593	0	8	0
404 (Hall)		74.3	16.8	500	0	10	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/11/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386235

ATC ASSOCIATES, INC.

Page 4 of 4

INDOOR AIR QUALITY FIELD REPORT

TIME 15:35LOCATION PS150 MDATE 3/11/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
402		72.9	16.0	490	0	9	0
Hall by Rest Rm.		74.5	17.3	509	0	11	0
401		73.6	16.3	499	0	8	0
Hall by West Stair.		74.7	17.0	516	0	12	0
501		72.9	16.0	501	0	8	0
502		72.8	15.8	531	0	7	0
(Hall) 502		74.9	16.8	525	0	13	0
Hall by Rest Rm.		74.6	16.6	536	0	14	0
503		73.0	16.0	549	0	9	0
504		73.4	15.4	540	0	10	0
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 3/11/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003386236