



ATHENICA
ENVIRONMENTAL SERVICES INC.

45-09 Greenpoint Avenue
Long Island City, N.Y. 11104

Tel (718) 784-7490
Fax (718) 784-4085

January 21, 2002

New York City School Construction Authority
30-30 Thomson Avenue
Long Island City, NY 11101

Attn: Ms. Marsha Soroka

Re: **Re-occupancy Letter for Economics H.S**
100 Trinity Pl.
Manhattan, NY

NYCSCA LLW #

JOB#

AES File #01-0613

Dear Ms. Soroka:

The final cleanup at the above referenced school was completed during January 10th & 11th of 2002. The Contractor (TRIO) performed the final cleanup in the following areas:

Final clean-up

- Basement, 1st, 2nd, 3rd, 4th, 5th, 6th, 7th, 8th, 9th, 10th, 11th and 12th floors.

The Q.C. ambient air samples were collected by Athenica Environmental Services, Inc., (AES) following the clean-up work in the aforementioned areas and transferred to AES, Inc., Laboratories, via chain-of-custody procedures. The samples were analyzed via Transmission Electron Microscopy (TEM) in accordance with applicable federal, AHERA, New York State, and New York City rules and regulations.

The results of the analysis of these samples indicated airborne concentrations to be less than 10 structures/cc by TEM analysis.

Based on Q.C. ambient air monitoring results, the final clean-up was completed in accordance with applicable federal, AHERA, New York State, and New York City rules and regulations. The cleaned spaces met all applicable criteria for reoccupancy.

Should you have any questions or need additional information, please do not hesitate to call me at (718) 784-7490.

Sincerely,

Vasilis Bellos
Senior Project Manager

Cc: School