

EMSL Analytical, Inc.

208 Stonchinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Taylor Environmental Group, Inc.

Floral Park Corporate Center

130-A Jericho Tpke.

Floral Park, NY 11001

Friday, January 11, 2002

Ref Number: LI02450

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: NYC. SCA: 100 Trinity Place, NYC.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			> 0.5µ < 5µ	Non- Asbestos ≥ 5µ			(S/mm ²)	(S/cc)
A-29	1283.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
A-30	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-31	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-32	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-33	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-34	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Michelle McGowan

Analyst


 Approved
 Signatory

Disclaimer: This laboratory is not responsible for data reported in structures, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYSAP or any agency of the U.S. Government. This report relates only to the samples analyzed above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

NYC-100-TRINITY PLACE, SCA-100, NY, NY 10038, CA, CLAD 0300, CT 01 0010

EMSL Analytical, Inc.

208 Stonehenge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn:

Taylor Environmental Group, Inc.

Floral Park Corporate Center

130-A Jericho Tpke.

Floral Park, NY 11001

Friday, January 11, 2002

Ref Number: LI02450

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: NYC. SCA: 100 Trinity Place, NYC.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			> 0.5µ < 5µ	Non- Asbestos ≥ 5µ			(S/mm ²)	(S/cc)
A-35	1350.00	Chrysotile	1	0	0.0635	0.0045	15.75	0.0045
A-36	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-37	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-38	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-39	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-40	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Michelle McGowan

Analyst

*Michelle McGowan*Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures. This report may not be reproduced, stored in full, without written approval by EMSL. This report must not be used to claim product endorsement by NPLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

2

JAN-14-2002 07:44

TAYLOR ENVIRONMENTAL

15163581780

P.14

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, January 11, 2002

Ref Number: LI02450

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: NYC. SCA: 100 Trinity Place, NYC.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			> 0.5µ - < 5µ	Non- Asbestos ≥ 5µ			(S/mm ³)	(S/cc)
A-41	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-42	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-43	1350.00	Chrysotile	3	0	0.0635	0.0045	47.24	0.0135
A-44	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-45	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-46	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Michelle McGowan

Analyst

Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYS or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts accuracy and precision) is available upon request.

3

CITY_21MC100_002947642

EMSL Analytical, Inc.

208 Sinnenhinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130-A Jericho Tpke.
 Floral Park, NY 11001

Friday, January 11, 2002

Ref Number: L102450

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: NYC. SCA: 100 Trinity Place, NYC.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			> 0.5µm < 5µm	≥ 5µm Non-Asbestos			(S/mm ³)	(S/cc)
A-47	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-48	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-49	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-50	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-51	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-52	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Michelle McGowan

Analyst

*Man Shoo*Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

4

EMSL Analytical, Inc.

208 Stonehenge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Taylor Environmental Group, Inc.

Floral Park Corporate Center

130-A Jericho Tpke

Floral Park, NY 11001

Friday, January 11, 2002

Ref Number: L102450

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: NYC. SCA: 100 Trinity Place, NYC.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			> 0.5 μ < 5 μ	Non- Asbestos $\geq$ 5 μ			(S/mm ²)	(S/cc)
A-53	1350.00	Chrysotile	1	0	0.0635	0.0045	15.75	0.0045
A-54	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-55	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-56	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-57	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
A-58	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Michelle McGowan

Analyst

Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYS or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

5

TOTAL P. 16

CITY_21MC100_002947644