

EMSL Analytical, Inc.

307 West 30th Street, New York, NY 10011

Phone: 212-390-0051 Fax: 212-290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001
 Fax: (516) 358-1790 Phone: 516-358-2955
 Project: M477-15217-29881 / NYCSCA / Stuyvesant HS, NY, NY /
 Various

Customer ID: TAYL50
 Customer PO:
 Received: 08/20/02 7:37 PM
 EMSL Order: 030211524
 EMSL Project ID:
 Analysis Date: 8/20/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures ≥ 0.5µ < 5µ	≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
S-1 030211524-0001	1275.00	0.0625	2	None Detected			0.0048	<16.00 <0.0048	
S-2 030211524-0002	1360.00	0.0625	0	None Detected			0.0045	<16.00 <0.0045	
S-3 030211524-0003	1360.00	0.0625	0	None Detected			0.0045	<16.00 <0.0045	
S-4 030211524-0004	1318.00	0.0625	0	None Detected			0.0047	<16.00 <0.0047	
S-5 030211524-0005	1360.00	0.0625	1	None Detected			0.0045	<16.00 <0.0045	
AF-6 030211524-0006	1360.00	0.0625	3	None Detected			0.0045	<16.00 <0.0045	
AF-7 030211524-0007	1615.00	0.0500	1	Chrysotile	2	0	0.0048	40 0.0095	
AF-8 030211524-0008	1360.00	0.0625	0	None Detected			0.0045	<16.00 <0.0045	
AF-9 030211524-0009	1318.00	0.0625	5	None Detected			0.0047	<16.00 <0.0047	
AF-10 030211524-0010	1275.00	0.0625	0	Chrysotile	6	0	0.0048	96 0.0280	
AS-11 030211524-0011	1360.00	0.0625	2	None Detected			0.0045	<16.00 <0.0045	

Analyst(s)

George Williams (12)

Ray Cross (8)


 Laboratory Manager
 or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by MVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst's accuracy and precision) is available upon request.

Accredited for MVLAP PLM/TEM #101048-A, NY State ELAP #11505

TEMAHERA-1

1

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10013

Phone: 212-280-0051 Fax: 212-280-0058 Email: manhattanlab@email.com

EMSL

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001

Fax: (516) 358-1780 Phone: 516-358-2955

Project: M477-16217-29881 / NYCSCA / Stuyvesant HS. NY, NY / Various

Customer ID: TAYLE0
 Customer PO:
 Received: 08/20/02 7:37 PM
 EMSL Order: 030211524
 EMSL Project ID:
 Analysis Date: 8/20/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures ≥ 0.5μ < 5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
AS-12 030211524-0012	1318.00	0.0625	0	None Detected		0.0047	<16.00	<0.0047	
AS-13 030211524-0013	1360.00	0.0625	0	None Detected		0.0045	<16.00	<0.0045	
AS-14 030211524-0014	1615.00	0.0625	0	None Detected		0.0038	<16.00	<0.0038	
AS-15 030211524-0015	1380.00	0.0625	0	None Detected		0.0045	<16.00	<0.0045	
O-16 030211524-0016	1275.00	0.0625	0	None Detected		0.0048	<16.00	<0.0048	
O-17 030211524-0017	1275.00	0.0625	4	None Detected		0.0048	<16.00	<0.0048	
O-18 030211524-0018	1360.00	0.0625	1	None Detected		0.0045	<16.00	<0.0045	
O-19 030211524-0019	1318.00	0.0625	0	None Detected		0.0047	<16.00	<0.0047	
O-20 030211524-0020	1380.00	0.0625	0	None Detected		0.0045	<16.00	<0.0045	

Analyst(s)

George Williams (12)
 Roy Cross (8)



Laboratory Manager
 or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

2

P.05 15163581780

TAYLOR ENVIRONMENTAL

SEP-06-2002 10:21

CITY_21MC100_002947664