

**ATHENICA**
ENVIRONMENTAL SERVICES INC.

45-09 Greenpoint Avenue
Long Island City, N.Y. 11104

Tel (718) 784-7490
Fax (718) 784-4085

January 24, 2002

New York City School Construction Authority
30-30 Thomson Avenue
Long Island City, NY 11101

Attn: Ms. Marsha Soroka

Re: Re-occupancy Letter for H.S of Leadership
90 Trinity PL
New York, NY

NYCSCA LLW #

JOB#

AES File #01-06 3

Dear Ms. Soroka:

The pre-clean-up at the above referenced school was completed during November 9-20 2001. The Contractor (KISS Construction) performed the pre-clean-up in the following areas:

Final clean-up.

- Basement, 1st, 2nd, 3rd, 4th, 5th, 6th, 7th, 8th, 9th, 10th, 11th, 12th, 13th, 14th and 15th floors.


The Q.C ambient air samples were collected by Athenica Environmental Services, Inc. (AES) following the clean-up work in the aforementioned areas and transferred to AES Laboratories, via chain-of-custody procedures. The samples were analyzed via Phase Contrast Microscopy (PCM) in accordance with applicable federal, AHERA, New York State, and New York City rules and regulations.

The results of the analyses of these samples indicated airborne concentrations to be less than 0.01 fibers per cubic centimeter of air (<0.01 f/cc) by PCM analysis.

The pre-clean-up was completed in accordance with applicable federal, AHERA, New York State, and New York City rules and regulations. Based on Q.C ambient air monitoring results, the cleaned spaces met all applicable criteria for reoccupancy.

Should you have any questions or need additional information, please do not hesitate to call me at (718) 784-7490.

Sincerely,



Kyriacos Diakou
Project Manager

Cc: Principal
Custodian