

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSL

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
150 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 358-1780

Phone: 516-358-2955

Project: 100 Trinity Pl

Customer ID: TAYL50

Customer PO:

Received: 01/10/02 7:00 PM

EMSL Order: 030200447


EMSL Project ID:

Analysis Date: 1/10/2002

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structure 0.5µ-5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/nm ²) (S/cc)	Notes
A-01 030200447-0001	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-02 030200447-0002	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-03 030200447-0003	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-04 030200447-0004	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-05 030200447-0005	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-06 030200447-0006	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-07 030200447-0007	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-08 030200447-0008	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-09 030200447-0009	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-10 030200447-0010	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-11 030200447-0011	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	

George William (28)



Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/nm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% performance limits and laboratory and analytical accuracy and precision) is available upon request.

Accredited by NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEM/AHERA-1

1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-280-0851 Fax: 212-250-0058 Email:

EMSL

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 358-1780
Project: 100 Trinity Pl

Phone: 516-358-2955

Customer ID: TAYL50

Customer PO:

Received: 01/10/02 7:00 PM

EMSL Order: 030200447

EMSL Project ID:

Analysis Date: 1/10/2002

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
A-12 030200447-0012	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-13 030200447-0013	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-14 030200447-0014	1283.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
A-15 030200447-0015	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-16 030200447-0016	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-17 030200447-0017	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-18 030200447-0018	1283.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
A-19 030200447-0019	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-20 030200447-0020	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-21 030200447-0021	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-22 030200447-0022	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (28)

Eric B. [Signature]
Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NVLAP PL/TEM #101548-9, NY State ELAP #11506

TEMAHERA-1

2

New York Lab

307 West 35th Street, New York, NY 10018

Phone: 212-390-0051 Fax: 212-390-0058 Email:

EMSL

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke
Floral Park, NY 11001

Fax: (516) 358-1780

Phone: 516-358-2955

Project: 100 Trinity Pl

Customer ID: TAYL50

Customer PO:

Received: 01/10/02 7:00 PM

EMSL Order: 030200447

EMSL Project ID:

Analysis Date: 1/10/2002

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ-5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
A-23 030200447-0023	1317.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
A-24 030200447-0024	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-25 030200447-0025	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
A-26 030200447-0026	1263.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
A-27 030200447-0027	1283.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
A-28 030200447-0028	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (28)



Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, stored in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NVLAP PLU/TEM #101043-9 NYS Lab ELAP #11526

TEM/AHERA-1

3