

0001

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0830

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____

P.O. _____

CLIENT: NYC SCAPROJECT: PS 234 MLOCATION: Basement 3rd & 2nd floorW&P FILE #: 1030-53-01LABORATORY: ATCANALYSIS METHOD: PCM / TEM
circle one 7400 AHERA EPA LEVEL IICONTACT: KWAME

LLW#: _____

SCA JOB#: _____

TECHNICIAN: David Mullohan / FATED E.C. 10/16/01

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc)
01	3rd floor Room 301	5		9	9	1640	1855	135	1250	<14.8
02	3rd floor Room 308 (TEG DC #1)	5		9	9	1643	1858	135	1250	<14.8
03	3rd floor hallway between R 313 and 315 (TEG DC #2)	5		9	9	1645	1900	135	1215	<14.8
04	Stairway & Hallway #3	5		9	9	1648	1903	135	1215	<14.8
05	Room 322	5		9	9	1650	1905	135	1215	<14.8
06	Room 201 Library (TEG DC #3)	5		9	9	1658	1913	135	1215	<14.8
07	Room 206 Auditorium (TEG DC #4)	5		9	9	1700	1915	135	1215	<14.8
08	2nd floor in the hallway	5		9	9	1703	1918	135	1215	14.8
09	Room 229	5		9	9	1708	1920	135	1215	<14.8
10	Room 222	5		9	9	1708	1923	135	1215	<14.8
11	Basement floor by elevator	5		9	9	1713	1928	135	1215	<14.8
12	BIT in Basement	5		9	9	1715	1930	135	1215	<14.8
13	Basement corridor by R313 (TEG DC #5)	5		9	9	1717	1932	135	1215	<14.8

COMMENTS:

SAMPLE BY: <u>David Mullohan</u>	DATE: <u>10/16/01</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>David Mullohan</u>	DATE: <u>10/16/01</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: <u>ATC By RPEXAKUN</u>	DATE: <u>10.16.01</u>
SIGNATURE: <u>[Signature]</u>	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ATC ENVIRONMENTAL

10/16/01 TUE 21:10 FAX 212 598 4283

CITY_21MC100_007115362

0002

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 2 OF 2

P.O. _____

CLIENT: NYC SCAW&P FILE #: 1030-53-01

CONTACT: _____

PROJECT: PS 234 MLABORATORY: ATC

LLW#: _____

LOCATION: Basement, 3rd, 2nd, 1st floorsANALYSIS METHOD: PCM TEM TEM
7400 AHERA EPA LEVEL II

SCA JOB#: _____

TECHNICIAN: David Mullokanov / FAYED EL-GHENDI

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTR. (lb/cu m)
				START	STOP	ON	OFF			
14	Basement Boiler Room West Side (TEG Q.C. #6)	5		9	9	1719	1934	185	1215	<14.8
15	Basement B2	5		9	9	1721	1936	185	1215	<14.8
16	First Floor Room 101	5		9	9	1732	1947	135	1215	<14.8
17	GYM Room (TEG Q.C. #7)	5		9	9	1738	1953	135	1215	<14.8
18	First Floor Inlet Ca. F.F. Entry (TEG Q.C. #8)	5		9	9	1743	1956	135	1215	<14.8
19	First Floor Hallway BY Room 107	5		9	9	1743	1958	135	1215	<14.8
20	First Floor Gym Room 118	5		9	9	1745	2000	135	1215	<14.8
21	Field Blank	1								
22	Field Blank	1								
23	Sealed Blank	1								

COMMENTS:

SAMPLE BY: <u>David Mullokanov</u>	DATE: <u>10/16/01</u>
SIGNATURE: <u>[Signature]</u> F. [Signature]	
RELEASED BY: <u>David Mullokanov</u>	DATE: <u>10/16/01</u>
SIGNATURE: <u>[Signature]</u> F. [Signature]	
RECEIVED BY: <u>ATC RFEYSKOV</u>	DATE: <u>10/16/01</u>
SIGNATURE: <u>[Signature]</u>	

SAMPLE TYPE CODES

- | | |
|------------------------------|-------------------------------|
| 1 - Blank | 5 - Final Clearance (inside) |
| 2 - Pre-Abatement | 6 - Final Clearance (outside) |
| 3 - During Abatement | 7 - Personal |
| 4 - During Glove Bag Removal | 8 - Background |

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ATC ENVIRONMENTAL

10/18/01 TUE 21:11 FAX 212 598 4283

CITY_21MC100_007115363