



104 East 25th Street
New York, New York 1001
www.atc-enviro.com
212.353.828
Fax 212.353.830

October 4, 2001

Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York, NY 10017
Attn: Mr. Fabio Pedone

Re: Report of TEM Analysis

Dear Mr. Pedone:

Following are the results of transmission electron microscopy (TEM) analysis of air samples from our Group No. 5605.

Client: NYCSCA
Address: P.S. 234, Warren St.
Location: Various Sites
Samples received: 10/04/01

These results will confirm and document the data transmitted to you by telephone and Fax today. The analyses were performed in strict conformance with the methodology of the AHERA Final Rule (CFR October 30, 1987) for clearance of abatement sites. As indicated on the attached Summary Results sheet, less than 70 asbestos structures per mm² was detected in all of the five inside samples submitted from the site by Warren and Panzer Engineers.

Results reported as Struct/cc are a function of air volume collected in the field and are, as such, not verifiable by this laboratory. This report may be reproduced only in its entirety and not without prior permission of this laboratory. If inside post-abatement samples pass, the response action may be considered to have been completed.

The analyses were supervised by Dr. Michael A. Gorycki, Director of Electron Microscopy.

We are pleased to note that our TEM lab has received full accreditation from NVLAP and also approval under the NY State DOH ELAP program, as is currently required for recognized analysis of TEM air samples for AHERA projects. These analyses were performed by ATC d/b/a ATC Associates Inc. Please contact me regarding any questions relating to these materials.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'Michael A. Gorycki', is written over a horizontal line.

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy

296

CITY_21MC100_010318575