

AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
 Phone: (516) 671-2370 - Fax: (516) 609-8271
 NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
 Address: One Liberty Plaza, 20th Floor
 New York, NY 10006
 Collected By: Rotimi Adeola
 Collected: 01/18/2005 6:08
 Rotometer: Standard


Job Number: 2043
 Date Received: 01/19/2005
 Date Analyzed: 01/25/2005
 Job Location: 130 Liberty Street

Lab ID Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures		Non- Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
						≥ 5µm <5µm	≥ 5µm				
0013942-001 26320-7	Washington Street/ Albany Street	6:08 14:08	4	1920	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013942-002 26320-8	Albany Street/ Greenwich Street	6:17 14:18	4	1924	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013942-003 26320-9	Greenwich Street	6:24 14:26	4	1928	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013942-004 26320-10	Liberty Street	6:35 14:38	4	1932	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013942-005 26320-11	Washington Street/ Cedar Street	6:44 14:48	4	1936	None Detected	0	0	0	0.0008	<0.0008	<3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Page 1 of 3

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
 This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
 This report relates only to the samples listed above.



AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
 Phone: (516) 671-2370 - Fax: (516) 609-8271
 NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
 Address: One Liberty Plaza, 20th Floor
 New York, NY 10006
 Collected By: Ike Onyenyili
 Collected: 01/18/2005 14:08
 Rotometer: Standard


Job Number: 2043
 Date Received: 01/19/2005
 Date Analyzed: 01/25/2005
 Job Location: 130 Liberty Street

Lab ID						Asbestos Structures		Non-Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
Field ID	Sample Location	Start/Stop	Flow	Volume (liters)	Asbestos Type(s)	≥ 5µm <5µm	≥ 5µm				
0013943-001	Washington Street/ Albany Street	14:08 22:08	4	1920	None Detected	0	0	0	0.0008	<0.0008	<3.98
26324-7											
0013943-002	Albany Street/ Greenwich Street	14:18 22:10	4	1888	None Detected	0	0	0	0.0008	<0.0008	<3.79
26324-8											
0013943-003	Greenwich Street	14:26 22:15	4	1876	None Detected	0	0	0	0.0008	<0.0008	<3.79
26324-9											
0013943-004	Liberty Street	14:38 22:21	4	1852	None Detected	0	0	0	0.0008	<0.0008	<3.79
26324-10											
0013943-005	Washington Street/ Cedar Street	14:48 22:27	4	1836	None Detected	0	0	0	0.0008	<0.0008	<3.79
26324-11											

SIGNED FOR AMBIENT GROUP, INC. BY:

Page 2 of 3

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
 This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
 This report relates only to the samples listed above.



AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
 Phone: (516) 671-2370 - Fax: (516) 609-8271
 NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
 Address: One Liberty Plaza, 20th Floor
 New York, NY 10006
 Collected By: Rotimi Adeola
 Collected: 01/18/2005 22:08
 Rotometer: Standard

Job Number: 2043
 Date Received: 01/19/2005
 Date Analyzed: 01/25/2005
 Job Location: 130 Liberty Street

Lab ID						Asbestos Structures			Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	$\geq 5\mu\text{m}$ <5 μm	$\geq 5\mu\text{m}$	Non- Asbestos			
0013944-001	Washington Street/ Albany Street	22:08 6:05	4	1908	None Detected	0	0	0	0.0008	<0.0008	<3.98
26325-7											
0013944-002	Albany Street/ Greenwich Street	22:10 6:11	4	1924	None Detected	0	0	0	0.0008	<0.0008	<3.98
26325-8											
0013944-003	Greenwich Street	22:15 6:16	4	1924	None Detected	0	0	0	0.0008	<0.0008	<3.98
26325-9											
0013944-004	Liberty Street	22:21 6:25	4	1936	None Detected	0	0	0	0.0008	<0.0008	<3.98
26325-10											
0013944-005	Washington Street/ Cedar Street	22:27 6:34	4	1948	None Detected	0	0	0	0.0008	<0.0008	<3.98
26325-11											

Average Filter Loading: <3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Page 3 of 3

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
 This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
 This report relates only to the samples listed above.

CITY_DEP_WORBY_CANNATA_SUBP_000078801