NYC 9/11 Public Portal Document

ATHENICA
ENVIRONMENTAL SERVICES
(718) 784-7490
FAX (718) 784-4085

CLIENT: SCHOOL CONSTRUCTION AUTHORITY
SITE: LDSHP HS 90 TRINITY PL
PROJECT NO: 01-0603
DATE: November 20, 2001
PURPOSE OF MONITORING: AREA SAMPLING
TECHNICIAN: G. LOPEZ
CASET SIZE: 25mm
ROTOMETER #: GL001
LOT #:
BATCH # 01-11-068

TYPE-OF-RESPIRATOR: HALF FACE
TYPE-OF-REMOVAL: CLEAN UP
COMMENTS: RM 1209,1103,1003,705,602,604, 607,713,6 FL BRDG-FINALS

SAMPLE ID #	LOCATION	(*) TYPE	PUMP	TIME IN	TIME OUT	TOTAL MIN.	FLOW BEFORE	FLOW AFTER	FLOW AVERAGE	VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
01	IN ROOM 1209 CENTER	IWA		01:00	02:30	90	14.0	14.0	14.0	1260	<.10	<.004
02	IN ROOM 1103 CENTER	IWA		01:01	02:31	90	14.0	14.0	14.0	1260	<.10	<.004
03	IN ROOM 1003 CENTER	IWA		01:02	02:32	90	14.0	14.0	14.0	1260	<.10	<.004
04	IN ROOM 705 CENTER	IWA		01:03	02:33	90	14.0	14.0	14.0	1260	<.10	<.004
05	IN ROOM 713 CENTER	IWA		01:04	02:34	90	14.0	14.0	14.0	1260	0.10	0.004
06	IN ROOM 602 CENTER	IWA		01:05	02:35	90	14.0	14.0	14.0	1260	<.10	<.004
07	IN ROOM 604 CENTER	IWA		01:06	02:36	90	14.0	14.0	14.0	1260	<.10	<.004
08	IN ROOM 607 CENTER	IWA		01:07	02:37	90	14.0	14.0	14.0	1260	<.10	<.004
09	6TH FL BRIDGE OPP RM 605	IWA		01:08	02:38	90	14.0	14.0	14.0	1260	<.10	<.004
10	IN ROOM 713	IWA		01:09	02:39	90	14.0	14.0	14.0	1260	<.10	<.004
11	FIELD BLANK										0.00	
12	FIELD BLANK										0.00	

* OWA -Outside work area
IWA -Inside work area
ICR -Inside clean room
IFNL -Inside Finals
OFNL -Outside Finals
PRE -Preabatement
OB -Outside building
NGAE -Negative air exhaust
OTH -Other

Above samples analyzed by Phase Contrast Microscopy (PCM) per NIOSH 7400 Method (ELAP # 10955). Analyzed By :

Spiro I. Dongaris,
Laboratory Director

Athenica Environmental Services Inc. (AES) is responsible only for information pertaining to samples taken by its employees. AES shall not be liable for information arising from samples that are not [redacted] its QC and QA programs.

12/07/2001 11:01 FAX 718 784 4085 002
CITY_21MC100_0030765 80
NYC-WTC_000232324