

ATC ASSOCIATES, INC**104 E 25th Street, 10th Floor****New York, NY 10010****Tel. 212-353-8280****Fax 212-353-8306**

REPORT DATE: 08-29-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
Stuyvesant H. S.- Auditorium

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 08-29-02
DATE RECEIVED: 08-29-02
DATE ANALYZED: 08-29-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
AL-1	21608	Auditorium Balcony North	<1.4	1.4
AL-2	21608	Auditorium Balcony South	<1.4	1.4
AL-3	21608	Auditorium Lower Level 15' of North Exit	<1.4	1.4
AL-4	21608	Auditorium Lower Level 15' of South Exit	<1.4	1.4
AL-5	21608	Auditorium Storage Center	<1.4	1.4
FB1	21608	Field Blank	<1.5 μg	1.5 μg
FB2	21608	Field Blank	<1.5 μg	1.5 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 3.0 μg

NOTE 2:

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.

NOTE 3:

Blank units are in μg

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

ED

REPORT PREPARED BY: _____

[Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

[Signature]

LABORATORY DIRECTOR: _____

24.6.

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).