NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217-29881 / NYC-SCA / STUYVESANT H.S. NY, NY / 10TH FLOOR / POST

Customer ID: TAYL50
Customer PO:
Received: 08/20/02 7:25 AM
EMSL Order: 030211480
EMSL Project ID:
Analysis Date: 8/20/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures ≥ 0.5μ < 5	# Structures ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
10-T1 *030211480-0001*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T2 *030211480-0002*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T3 *030211480-0003*	1260.00	0.0625	1	None Detected			0.0049	<16.00	<0.0049	
10-T4 *030211480-0004*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T5 *030211480-0005*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T6 *030211480-0006*	1260.00	0.0625	1	None Detected			0.0049	<16.00	<0.0049	
10-T7 *030211480-0007*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T8 *030211480-0008*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T9 *030211480-0009*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	
10-T10 *030211480-0010*	1260.00	0.0625	0	None Detected			0.0049	<16.00	<0.0049	

Analyst(s)
Ghayath Elias (10)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.
Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11509

TEMAHERA-1

CITY_21MC100_010218303

NYC-WTC_000232361