

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

REPORT DATE: 08-20-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
7th Floor

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 08-20-02

DATE RECEIVED: 08-20-02

DATE ANALYZED: 08-20-02

SAMPLE MEDIA: Air Samples

ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
7-L1	21331	Corridor West Side by Rm 739	<1.3	1.3
7-L2	21331	Inside Rm 731 South Side	<1.3	1.3
7-L3	21331	Corridor Middle Side by Escalator	<1.3	1.3
7-L4	21331	Corridor East Side by Rm 707	<1.4	1.4
7-L5	21331	Inside Rm 702A	<1.4	1.4
FB1	21331	Field Blank	<1.5 μg	1.5 μg
FB2	21331	Field Blank	<1.5 μg	1.5 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 3.0 μg

NOTE 2:

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.

NOTE 3:

Blank units are in μg

NOTE 4:

Samples prepared by ESML

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: ML

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: ML

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).