

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-17-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers St., NY

SAMPLED BY: Client

SAMPLE DATE 07-16-02
DATE RECEIVED: 07-16-02
DATE ANALYZED: 07-16-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
LW-01	20409	Rm 901 East Side Unitvent Rear	14.3	9.0
LW-02	20409	Rm 903 South Side Left Unitvent Rear	16.1	9.0
LW-03	20409	Rm 903 South Side Middle Unitvent Rear	9.5	9.0
LW-04	20409	Rm 903 South Side Right Unitvent Rear	12.0	9.0
LW-05	20409	Rm 907 South Side Unitvent Rear	12.7	9.0
LW-06	20409	Rm 911 South Side Left Unitvent Rear	15.8	9.0
LW-07	20409	Rm 911 South Side Right Unitvent Rear	30.3	9.0
FBL-1	20409	Field Blank	<9.0 μg	9.0 μg
FBL-2	20409	Field Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: *HEU*

REPORT PREPARED BY: *[Signature]*

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: *ms*

LABORATORY DIRECTOR: *ML*

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).