NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-13-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE: 08-13-02
DATE RECEIVED: 08-13-02
DATE ANALYZED: 08-13-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
LW-19	21096	Rm K550A Floor 3' of Entrance	<9.0	9.0
LW-20	21096	Rm K550A Locker #6	<9.0	9.0
LW-21	21096	Rm C550B Floor	<9.0	9.0
LW-22	21096	Rm K550C Floor 3' of Entrance	<9.0	9.0
LW-23	21096	Rm K550C Locker #23	<9.0	9.0
LW-24	21096	Rm K550D Floor	10.2	9.0
LW-25	21096	Rm K550D Top of Metal Tabel (Left Side)	12.4	9.0
LW-26	21096	Rm K550E Floor Center of Rm	10.9	9.0
LW-27	21096	Rm K550E Top of Cardboard Box	13.7	9.0
LW-28	21096	Rm K550J Floor at Entrance	12.1	9.0
LW-29	21096	Rm K550K Floor Center of Rm	<9.0	9.0
LW-30	21096	Rm K550K Top of File Cabinet	13.9	9.0
LW-31	21096	Rm K550L Floor of Center	12.9	9.0
LW-32	21096	Rm K550L Top of Regrigeration	24.2	9.0
LW-33	21096	Kitchen Floor by South Center Column	<9.0	9.0

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

LW-34	21096	Kitchen Top of South Center Sink Table	<9.0	9.0
LW-35	21096	Rm K540B Floor Center	<9.0	9.0
LW-36	21096	Rm K54D B Table Top North Side	<9.0	9.0
LW-37	21096	Rm K540C Floor Center	<9.0	9.0
LW-38	21096	Rm K540C Table Top	<9.0	9.0
LW-39	21096	Rm K540A Floor Center	<9.0	9.0
LW-40	21096	Rm K540A Top of Middle Service Counter	<9.0	9.0
LW-41	21096	Cafeteria Floor Center	<9.0	9.0
LW-42	21096	Cafeteria Table Top NE Side	<9.0	9.0
LW-43	21096	Rm C540D Floor 3' of Entrance	<9.0	9.0
LW-44	21096	Rm C540E Floor 3' of Entrance	<9.0	9.0
LW-45	21096	Rm C528 Service Elev. Lobby Floor	<9.0	9.0
FBL-1	21096	Field Blank	<9.0 µg	9.0 µg
FBL-2	21096	Field Blank	<9.0 µg	9.0 µg
FBL-3	21096	Field Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY:_____

REPORT PREPARED BY:_____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:_____

LABORATORY DIRECTOR:_____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).