

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 09-03-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: NYC SCA/Stuyvesant HS
345 Chambers St., NY, NY

SAMPLED BY: Client

SAMPLE DATE: 08-30-02
DATE RECEIVED: 08-30-02
DATE ANALYZED: 08-30-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
LW-01	21705	Rm 132A Floor at Entrance	<9.0	9.0
LW-02	21705	Rm 132A Desk Top	<9.0	9.0
FBL-1	21705	Field Blank	<9.0 μg	9.0 μg
FBL-2	21705	Field Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg **CERTIFICATION AND SIGNATURES****ANALYSIS PERFORMED BY:** TCY**REPORT PREPARED BY:** tytll

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: amb**LABORATORY DIRECTOR:** ML

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).