

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001

Fax: (516) 358-1780

Phone: 516-358-2955

Project: M477-15217-29881 / Stuyvesant H.S. 345 Chambers ST,
 NY / NYC SCA

Customer ID: TAYL50

Customer PO:

Received: 08/24/02 1:10 AM

EMSL Order: 030211734

EMSL Project ID:

Analysis Date: 8/24/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					$\geq 0.5\mu$	$< 5\mu$		(S/mm ²)	(S/cc)	
PO-01 030211734-0001	1350.00	0.0625	2	None Detected			0.0046	<16.00	<0.0046	
PO-02 030211734-0002	1275.00	0.0625	2	None Detected			0.0048	<16.00	<0.0048	
PO-03 030211734-0003	1350.00	0.0625	1	None Detected			0.0046	<16.00	<0.0046	
PO-04 030211734-0004	1350.00	0.0625	4	None Detected			0.0046	<16.00	<0.0046	
PO-05 030211734-0005	1275.00	0.0625	0	Anthophyllite	0	1	0.0048	16	0.0048	
				Chrysotile	1	0		16	0.0048	
				Total for all types.....				32	0.0097	
PO-06 030211734-0006	1313.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	
PO-07 030211734-0007	1350.00	0.0625	0	None Detected			0.0046	<16.00	<0.0046	
PO-08 030211734-0008	1350.00	0.0625	0	None Detected			0.0046	<16.00	<0.0046	
PO-09 030211734-0009	1313.00	0.0625	1	None Detected			0.0047	<16.00	<0.0047	
PO-10 030211734-0010	1350.00	0.0625	0	None Detected			0.0046	<16.00	<0.0046	

Revised Report on 8/24/02

Analyst(s)

George Williams (10)



Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

1

CITY_21MC100_003123084