

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001

030210871

RECEIVED
EMSL MANHATTAN

516-358-2955
Fax 516-358-1780

LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS SCA Stuyvesant HS		CONTACT: Hamid Savoi		SAMPLER (SIGNATURE) <i>Carlos J. J. J.</i>		DATE 02 AUG 03		TIME PM 4:20		SAMPLE(S) SEALED ☒ YES ☐ NO	
PROJECT LOCATION: 345 Chambers St.		PROJECT # m477-15217/29881		SAMPLER NAME (PRINT) CARLOS J. J. J.						CORRECT CONTAINER(S) ☒ YES ☐ NO	
SAMPLE INFORMATION:				MATRIX (CIRCLE ONE): ☒ WIPB ☐ PAINT ☐ SOIL ☐ OTHER							
LABORATORY #	SAMPLE #	LOCATION	AREA (FT ²)	SURFACE MATERIAL				LAB RESULT			
				WOOD	METAL	BRICK	OTHER				
	1	2nd floor MER HVAC 5 Supply Liner	1				Fg.	<div style="text-align: center;"> < 10.0 </div>			
	2	2nd floor MER HVAC 6 return Liner	1				Fg				
	3	2nd floor MER HVAC 6 Supply Liner	1				Fg				
	4	2nd floor MER HVAC 6 return Louvre	1		X						
	5	4th floor MER HVAC 3 Supply Liner	1				Rg				
	6	4th floor MER HVAC 4 Supply Liner	1				Fg				
	7	6th floor roof HVAC 13 Supply Liner	1				Rg				
	8	6th floor roof HVAC 13 return Liner	1				Fg				
Fax 516-358-1780 212-406-2535				TURNAROUND REQUIRED: 6 hrs NORMAL ☐ STAT ☐ BY 1/1				COMMENTS / INSTRUCTIONS Fg = F. Briggs			
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>		DATE 8/8/02 TIME 16:30		PRINTED NAME A. KRAVCHUK		RECEIVED BY (SIGNATURE) <i>Elsi Quispe</i>		DATE 8/8/02 TIME 4:30 PM		PRINTED NAME	
RELINQUISHED BY (SIGNATURE)		DATE TIME		PRINTED NAME		RECEIVED BY LAB (SIGNATURE)		DATE TIME		PRINTED NAME	

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

CITY_21MC100_010236667

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001

030210871

80 2072

516-358-2955
Fax 516-358-1780

LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS <i>SCA</i> <i>Sturveson 179</i>		CONTACT: <i>Homid Savos</i>		SAMPLER (SIGNATURE) <i>[Signature]</i>		DATE <i>8-8-02</i>		SAMPLE(S) SEALED YES / NO	
PROJECT LOCATION: <i>345 Chambers St</i>		PROJECT # <i>m477-15217/29881</i>		SAMPLER NAME (PRINT) <i>CARDOS JORDAN</i>				CORRECT CONTAINER(S) YES / NO	
SAMPLE INFORMATION:				MATRIX (CIRCLE ONE): ☒ WIPE ☐ PAINT ☐ SOIL ☐ OTHER _____					
LABORATORY #	SAMPLE #	LOCATION	AREA (FT ²)	SURFACE MATERIAL				LAB RESULT	
				WOOD	METAL	BRICK	OTHER		
	FB-1	<i>Field Blk 1</i>	<i>—</i>					<i>—</i>	
	FB-2	<i>Field Blk 1</i>	<i>—</i>					<i>—</i>	
				TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY <i>/ /</i>				COMMENTS / INSTRUCTIONS	
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>		DATE <i>8/8/02</i> TIME <i>16:30</i>	PRINTED NAME <i>A. Vazquez</i>		RECEIVED BY (SIGNATURE) <i>[Signature]</i>		DATE <i>8/8/02</i> TIME <i>4:30 PM</i>	PRINTED NAME	
RELINQUISHED BY (SIGNATURE)		DATE	PRINTED NAME		RECEIVED BY LAB (SIGNATURE)		DATE	PRINTED NAME	
		TIME					TIME		

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

CITY_21MC100_010236668

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com



Attr:	Taylor Environmental Group, Inc. Floral Park Corporate Center 130 Jericho Tpke. Floral Park, NY 11001	Customer ID:	TAYL50
Fax:	(516) 358-1780	Customer PO:	
Project:	M477-15217 / 29881 / SCA / Stuyvesant HS / 345 Chambers St	Received:	08/08/02 4:28 PM
	Phone: 516-358-2955	EMSL Order:	030210871
		EMSL Project ID:	

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration	Notes
1 2nd floor MER HVAC5 Supply Liner	0001	8/8/02	144 in ²	<10.0 µg/ft ²	
2 2nd floor MER HVAC 6 Return Liner	0002	8/8/02	144 in ²	<10.0 µg/ft ²	
3 2nd floor MER HVAC 6 Supply Liner	0003	8/8/02	144 in ²	<10.0 µg/ft ²	
4 2nd floor MER HVAC 6 Return Louvre	0004	8/8/02	144 in ²	<10.0 µg/ft ²	
5 4th floor MER HVAC 3 Supply Liner	0005	8/8/02	144 in ²	<10.0 µg/ft ²	
6 4th floor MER HVAC 4 Supply Liner	0006	8/8/02	144 in ²	<10.0 µg/ft ²	
7 6th floor Roof HVAC 13 Supply Liner	0007	8/8/02	144 in ²	<10.0 µg/ft ²	
8 6th floor Roof HVAC 13 Return Liner	0008	8/8/02	144 in ²	<10.0 µg/ft ²	
FB-1 Field blank	0009	8/8/02	n/a	<10.0 µg/wipe	
FB-2 Field blank	0010	8/8/02	n/a	<10.0 µg/wipe	

M. Apfeldorfer
Laboratory Manager
or other approved signatory / ANALYST

Reporting limit is 10 µg/wipe

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581