

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001

030211418

516-358-2955
Fax 516-358-1780

LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS NYC SCA			CONTACT: HAMID SAUDJ			SAMPLER (SIGNATURE) <i>Carlos Jofre</i>		DATE 8-17-02		TIME		SAMPLE(S) SEALED ☒ YES / ☐ NO							
PROJECT LOCATION: Stuyvesant HS			PROJECT # M477-15217/29881			SAMPLER NAME (PRINT) CARLOS JOFRE						CORRECT CONTAINER(S) ☒ YES / ☐ NO							
						MATRIX (CIRCLE ONE) ☒ WIPE		☐ PAINT		☐ SOIL		☐ OTHER							
SAMPLE INFORMATION:						AREA (FT ²)		SURFACE MATERIAL				LAB RESULT							
LABORATORY #		SAMPLE #		LOCATION				WOOD		METAL		BRICK		OTHER					
		LW-01		1 st FLOOR CORRIDOR O/S THEATER ENTRANCE (RETURN)		1 FT ²				☒						< 10.0			
		FB 1		(10.1024) FIELD BLANK												-			
		FB 2		FIELD BLANK												-			
						TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY 1 / 1						COMMENTS / INSTRUCTIONS 6 HRS ³⁰ TAT							
RELINQUISHED BY (SIGNATURE) <i>C. McFuzano</i>				DATE 8/17/02		PRINTED NAME C. McFuzano				RECEIVED BY (SIGNATURE) <i>Chayal Shis</i>				DATE 8/17		PRINTED NAME			
				TIME 2:47p										TIME 5:45pm					
RELINQUISHED BY (SIGNATURE)				DATE		PRINTED NAME				RECEIVED BY LAB (SIGNATURE)				DATE		PRINTED NAME			
				TIME										TIME					

02 AUG 17 PM 5:45

EAST MANHATTAN
RECEIVED

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

CITY_21MC100_010236692

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

The EMSL logo is a black diamond shape with the letters "EMSL" in white, bold, sans-serif font inside.Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 358-1780 Phone: 516-358-2955

Project: M477-15217/29881 / NYCSCA/ STUYVESANT H.S.

Customer ID: TAYL50

Customer PO:

Received: 08/17/02 5:45 PM

EMSL Order: 030211419

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description		Lab ID	Analyzed	Area Sampled	Lead Concentration	Notes
LW-01	1ST FLR CORRIDOR O/S THEATER ENTRANCE	0001	8/17/2002	144 in ²	<10.0 µg/ft ²	
FB1	Field blank	0002	8/17/2002	n/a	<10.0 µg/wipe	
FB2	Field blank	0003	8/17/2002	n/a	<10.0 µg/wipe	

A handwritten signature in black ink, appearing to read "Sammy Man", is written over the printed text "Laboratory Manager or other approved signatory".
Laboratory Manager
or other approved signatory

Reporting limit is 10 ug/wipe

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581