

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001

21042

516-358-2955
Fax 516-358-1780

LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS NYCSCA Stuyvesant H.S.		CONTACT: HARRY SAVOY		SAMPLER (SIGNATURE) Carlos A. Lopez		DATE 8/9/02		TIME 11:40		SAMPLE(S) SEALED ☒ YES ☐ NO			
PROJECT LOCATION: CAMBODS ST, NY, NY		PROJECT # M477-15217/29851		SAMPLER NAME (PRINT) CARLOS LOPEZ		CORRECT CONTAINER(S) ☒ YES ☐ NO							
SAMPLE INFORMATION:				MATRIX (CIRCLE ONE): ☒ WIPE ☐ PAINT ☐ SOIL ☐ OTHER									
LABORATORY #		SAMPLE #		LOCATION		AREA (FT ²)		SURFACE MATERIAL				LAB RESULT	
								WOOD METAL BRICK OTHER					
		LW-01		6TH FL DANCO STUDIO FLOOR ADJ. LEFT WINDOW		1.0		☒ X				49.0	
		LW-02		6TH FL DANCO STUDIO TABLE TOP - R.H.S.		1.0		☒ X				49.0	
		FB-1		F/BLANK		—						49.0	
		FB-2		F/BLANK		—						49.0	
TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY 1/1						COMMENTS / INSTRUCTIONS 642 YAT							
RELINQUISHED BY (SIGNATURE) Carlos A. Lopez		DATE 8-9-02 TIME 17:00		PRINTED NAME C. Lopez		RECEIVED BY (SIGNATURE) AFC Lab / [Signature]		DATE 08/09/02		PRINTED NAME D. KOGAN			
RELINQUISHED BY (SIGNATURE) [Signature]		DATE 8/9/02 TIME 5:30		PRINTED NAME S. Francis		RECEIVED BY LAB (SIGNATURE) AFC Lab / [Signature]		DATE 08/09/02		PRINTED NAME D. KOGAN			

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-12-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE: 08-09-02
DATE RECEIVED: 08-09-02
DATE ANALYZED: 08-09-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
LW-01	21042	6th Floor Dance Studio Floor Adj.Left Window	<9.0	9.0
LW-02	21042	6th Floor Dance Studio Table Top R.H.S.	<9.0	9.0
FB-1	21042	Field Blank	<9.0 µg	9.0 µg
FB-2	21042	Field Blank	<9.0 µg	9.0 µg

NOTE 1:


THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:



HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES**ANALYSIS PERFORMED BY:** **REPORT PREPARED BY:** 

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: **LABORATORY DIRECTOR:** 

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).