

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-26-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-26-02
DATE RECEIVED: 07-26-02
DATE ANALYZED: 07-26-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
W-01	20677	Rm 435 South Side Left Unitvent (Back Wall)	9.4	9.0
W-02	20677	Rm 435 South Side Right Unitvent (Back Wall)	14.6	9.0
W-03	20677	Rm 450 Unitvent (Back Wall)	<9.0	9.0
W-04	20677	Rm 315 South Side Left Unitvent (Back Wall)	<9.0	9.0
W-05	20677	Rm 315 South Side Right Unitvent (Back Wall)	<9.0	9.0
W-06	20677	Rm 307 South Side Left Unitvent (Back Wall)	<9.0	9.0
W-07	20677	Rm 307 South Side Middle Unitvent (Back Wall)	<9.0	9.0
W-08	20677	Rm 307 South Side Right Unitvent (Back Wall)	<9.0	9.0
W-09	20677	Field Blank	<9.0 µg	9.0 µg
W-10	20677	Field Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft².
 Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg