

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-25-02
CLIENT: Taylor Environmental Group, Inc.
PROJECT NAME: SCA/Stuyvesant HS
4th Floor
PROJECT NUMBER: M477-15217/29881
SAMPLED BY: Client
SAMPLE DATE 07-25-02
DATE RECEIVED: 07-25-02
DATE ANALYZED: 07-25-02
SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
01	20635	Rm 401 at Entrance	<3.6	3.6
02	20635	Rm 403 at Entrance	<3.6	3.6
03	20635	Rm 404 at Entrance	<3.6	3.6
04	20635	Rm 405 at Entrance	<3.6	3.6
05	20635	Rm 407 at Entrance	<3.6	3.6
06	20635	Rm 411 at Entrance	5.2	3.6
07	20635	Rm 413 at Entrance	<3.6	3.6
08	20635	Rm 911 at Entrance	<3.6	3.6
09	20635	Rm 401 at Entrance	<3.1	3.1
10	20635	Rm 403 at Entrance	6.1	4.2
11	20635	Rm 404 at Entrance	4.7	3.1
12	20635	Rm 405 at Entrance	<4.2	4.2
13	20635	Rm 407 at Entrance	<3.1	3.1
14	20635	Rm 411 at Entrance	<3.1	3.1
15	20635	Rm 413 at Entrance	<3.1	3.1

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

16	20635	Rm 427 at Entrance	<3.1	3.1
17	20635	Rm 429 at Entrance	<3.1	3.1
18	20635	Rm 431 at Entrance	<3.1	3.1
19	20635	Rm 911 at Entrance	<4.2	4.2
FB-20	20635	Field Blank	<1.5 µg	1.5 µg
FB-21	20635	Field Blank	<1.5 µg	1.5 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 3.0 µg

NOTE 2:

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: ED

REPORT PREPARED BY: MSD

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: MSD

LABORATORY DIRECTOR: MSD

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).