

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-09-02
CLIENT: Taylor Environmental Group, Inc.
PROJECT NAME: SCA/Stuyvesant HS
2nd Floor
PROJECT NUMBER: M477-15217/29881
SAMPLED BY: Client
SAMPLE DATE 08-08-02
DATE RECEIVED: 08-09-02
DATE ANALYZED: 08-09-02
SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
AL-01	21025	Rm 250 by Entrance	<2.0	2.0
AL-02	21025	Rm 251 by Entrance	<2.0	2.0
AL-03	21025	Rm 273 by Entrance	<2.0	2.0
BL3	21025	Field Blank	<1.5 μg	1.5 μg
BL4	21025	Field Blank	<1.5 μg	1.5 μg
AL-04	21025	In Rm 103 Center	<1.1	1.1
AL-05	21025	In Rm 105 by Door	<1.1	1.1
AL-06	21025	In Rm 103 Center	<1.3	1.3
AL-07	21025	In Rm 105 by Door	<1.3	1.3
BL1	21025	Field Blank	<1.5 μg	1.5 μg
BL2	21025	Field Blank	<1.5 μg	1.5 μg

NOTE 1:**THE REPORTING LIMIT (RL) IS 3.0 μg** **NOTE 2:**At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.**NOTE 3:**Blank units are in μg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

IL

REPORT PREPARED BY: _____

Ami

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

mmf

LABORATORY DIRECTOR: _____

M.L.

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).