

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email: manhattanlab@emsl.com



Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001
 Fax: (516) 358-1780 Phone: 516-358-2955
 Project: NYCSCA/STUYVESANT H.S./ AUDITORIUM/DURING

Customer ID: TAYL50
 Customer PO:
 Received: 08/24/02 7:15 PM
 EMSL Order: 030211774
 EMSL Project ID:
 Analysis Date: 8/24/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					$\geq 0.5\mu$	$< 5\mu$		(S/mm ²)	(S/cc)	
01 030211774-0001	1395.00	0.0625	0	None Detected			0.0044	<16.00	<0.0044	
02 030211774-0002	1318.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	
03 030211774-0003	1395.00	0.0625	0	None Detected			0.0044	<16.00	<0.0044	
04 030211774-0004	1395.00	0.0625	1	None Detected			0.0044	<16.00	<0.0044	
05 030211774-0005	1318.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	

José Arreaga

Analyst(s)

Rey Cross (5)

Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

1