

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001
 Fax: (516) 358-1780 Phone: 516-358-2955
 Project: M477-1521-7/29881 / STUYVESANT H.S./CHAMBERS
 ST., NY/DURING


Customer ID: TAYL50
 Customer PO:
 Received: 08/25/02 2:00 PM
 EMSL Order: 030211803
 EMSL Project ID:
 Analysis Date: 8/25/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					$\geq 0.5\mu < 5$	$\geq 5\mu$		(S/mm ²)	(S/cc)	
05 030211803-0001	1573.00	0.0500	1	Chrysotile	2	1	0.0049	60	0.0147	

Analyst(s)

Ghayath Elias (1)



Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

1

CITY_21MC100_010245552