

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

REPORT DATE: 07-22-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY
7th Floor

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-21-02
DATE RECEIVED: 07-21-02
DATE ANALYZED: 07-21-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
W-01	20523	Room #701 East Side Univent Back Wall	<9.0	9.0
W-02	20523	Room #701A East Side Univent Back Wall	<9.0	9.0
W-03	20523	Room #705 South Side Right Univent Back Wall	<9.0	9.0
W-04	20523	Room #705 South Side Left Univent Back Wall	<9.0	9.0
W-05	20523	Room #707 South Side Univent Back Wall	<9.0	9.0
W-06	20523	Room #709 South Side Left Univent Back Wall	<9.0	9.0
W-07	20523	Room #709 South Side Right Univent Back Wall	<9.0	9.0
W-08	20523	Field Blank	<9.0 μg	9.0 μg
W-09	20523	Field Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window walls 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CONFIDENTIAL,

CITY_21MC100_010733843

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008