

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

REPORT DATE: 07-17-02
CLIENT: Taylor Environmental Group, Inc.
PROJECT NAME: SCA/Stuyvesant HS
 345 Chambers St., 9th Floor
SAMPLED BY: Client
SAMPLE DATE 07-16-02
DATE RECEIVED: 07-16-02
DATE ANALYZED: 07-16-02
SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
01	20398	Rm 901 Inside Classroom Near Entrance to Corridor	<3.1	3.1
02	20398	Rm 903 Inside Classroom Near Entrance to Corridor	<3.1	3.1
03	20398	Rm 907 Inside Classroom Near Entrance to Corridor	<3.1	3.1
04	20398	Rm 911 Inside Classroom Near Entrance to Corridor	<3.1	3.1
05	20398	Rm 913 Inside Classroom Near Entrance to Corridor	<3.1	3.1
06	20398	Rm 925 Inside Classroom Near Entrance to Corridor	<2.5	2.5
07	20398	Rm 901 Inside Classroom Near Entrance to Corridor	<3.3	3.3
08	20398	Rm 903 Inside Classroom Near Entrance to Corridor	<3.3	3.3
09	20398	Rm 907 Inside Classroom Near Entrance to Corridor	<3.3	3.3
10	20398	Rm 911 Inside Classroom Near Entrance to Corridor	<3.4	3.4
11	20398	Rm 913 Inside Classroom Near Entrance to Corridor	<3.4	3.4
12	20398	Field Blank	<1.5 μg	1.5 μg
13	20398	Field Blank	<1.5 μg	1.5 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 3.0 μg

NOTE 2:

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.

NOTE 3:

Blank units are in μg

CONFIDENTIAL,

CITY_21MC100_010733862

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: JCU

REPORT PREPARED BY: JCU

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: RS

LABORATORY DIRECTOR: M.L.

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

CONFIDENTIAL,

CITY_21MC100_010733863

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008